



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B000169

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: MAY 2008**

**OWNER OF OPERATOR (Co.#2239)**

CalPortland Company  
19409 National Trails Hwy  
Oro Grande, CA 92368

**EQUIPMENT LOCATION (Fac.#3)**

CalPortland Oro Grande  
19409 National Trails Hwy  
Oro Grande, CA 92368

**Description:**

KILN AND CLINKER SYSTEM NO. 2 (120) consisting of:

**EQUIPMENT**

Capacity	Equipment Description
0	23-039 Boiler, Heat Recovery, Feed End Kiln No. 2
5	23-052 Screw Conveyor No. 52
35	44-011,015 Elevators; 2: No. 1 @ 25 hp , No. 5 @ 10 hp
30	44-033 Screw Conveyor No. 13
4	44-043,044 Screw Conveyors; 2: Nos. 23 & 24 @ 2 hp each
10	44-053,057 Screw Conveyors; 2: Nos. 33 & 37 @ 5 hp each
5	44-062 Screw Conveyor No. 42
150	44-162 Kiln No. 2 (130 MMBTUH)
15	44-172 Cooler No. 2 Fan, 10 + 5 hp
75	44-177 Cyclone, Buell
30	44-192 Heat Exchanger, 3 @ 10 hp
100	44-212,222 Fans; 2: Fan 2 @ 75 hp and Aux. Fan 2 @ 25 hp
15	44-232 Clinker Breaker
250	44-242 Coal Mill, CM 62
2.5	44-252 Feeder Belt, Coal Belt 2
1.5	44-262 Valve, Rotary, Coal Mill

Fee Schedule: 8 (f)

Rating: 131900000 Btu

SIC: 3241

SCC: 99999999

Location/UTM(Km):  
469E/3830N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CalPortland Company  
Attn: Catalina Elias

Oro Grande, CA 92368

By: **COPY**

**Brad Poiriez**

Air Pollution Control Officer

Capacity	Equipment Description
0	Total EQ HP + MMBTUH = 1.9 + 130 = 131.9

### CONDITIONS:

1. This equipment must not be operated unless it is vented to operating air pollution control equipment covered by valid District permit C000170 (44-152).
2. The owner/operator (o/o) shall comply with all District Rules and Regulations including, but not limited to, malfunction/breakdown notifications.
3. The o/o shall have a continuing program of maintenance/inspections in accord with manufacturer's recommendations and specifications which ensures compliance with District Rules.
4. The o/o shall maintain a log of all inspections, repairs and maintenance on this equipment and submit it to the District upon request. The log shall be kept for a minimum period of two years.
5. Daily logs shall be maintained for the operation of kiln No. 2 which includes but is not limited to the following:
  - A. Hours of operation/day,
  - B. Dates of major repairs and/or replacements,
  - C. Type of fuel being used and the Btu/h of each,
  - D. Dates of routine repairs.
6. The o/o shall comply with all requirements of Rule 1161 (Portland Cement Kilns) and provide to the District the following:
  - A. The daily emissions for each operating day for this kiln system shall be recorded and/or calculated in a manner approved by the District. The data shall be submitted to the District within 30 days of the end of each calendar quarter.
  - B. The o/o shall submit a written report of excess emissions to the District Compliance Supervisor for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.