



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B003331

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: AUGUST 2005

OWNER OF OPERATOR (Co.#15)

Pacific Gas & Electric/Air Permits
PO Box 7640
San Francisco, CA 94120

EQUIPMENT LOCATION (Fac.#535)

PG&E - Hinkley Compressor Station
35863 Fairview Road
Hinkley, CA 92347

Description:

NATURAL GAS FUELED IC ENGINE GENERATORS consisting of: Four Ingersol-Rand model PSVG, 8 cylinder 475 hp (4.32 MMBtu/hr) generators consuming 4110 scf/hr of natural gas as fuel and one Caterpillar model G379, 8 cylinder 330 hp (3.00 MMBtu/hr) generator consuming 2856 scf/hr of natural gas as fuel.

EQUIPMENT

Capacity	Equipment Description
475	P-1 Ingersol-Rand Serial No. 8APS111
475	P-2 Ingersol-Rand Serial No. 8APS112
475	P-3 Ingersol-Rand Serial No. 8APS109
475	P-4 Ingersol-Rand Serial No. 8APS135
330	P-5 Caterpillar Serial No. 72B323

CONDITIONS:

1. The applicant shall comply with all applicable District Rules and Regulations.
2. These IC engines shall be operated and maintained in strict accord with manufacturer's/supplier's recommendations and/or sound engineering principles.

Fee Schedule: 1 (d)

Rating: 2230 bhp

SIC: 4939

SCC: 20100201

Location/UTM(Km):
485E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pacific Gas & Electric/Air Permits
PO Box 7640
San Francisco, CA 94120

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

3. These engines shall only be fired on natural gas.