



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

B011548

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: APRIL 2025

OWNER OF OPERATOR (Co.#2442)

Storopack Inc.
4758 Devitt Drive
Cincinnati, OH 45246

EQUIPMENT LOCATION (Fac.#3349)

Storopack Inc.
9880 Rancho Rd.
Adelanto, CA 92301

Description:

BOILER, NATURAL GAS consisting of: Thermostream, Model FG60; Serial Number D1558, with a heat input rating of 2.5 MMBtu/hr, fueled exclusively on Natural Gas. Facility Elevation is 2949 feet above sea level.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or in a manner consistent with safety and good air pollution control practices for minimizing emissions. Furthermore, operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued.
[District Rule 1303(B)]
2. This equipment is limited to using only PUC-Regulated pipeline quality natural gas for fuel.
[District Rules 431 and 1303(B)]
3. A non-resettable four-digit (9,999) hour timer and/or fuel meter shall be installed and maintained on this unit to indicate elapsed unit operating time and/or fuel consumption. In-lieu of a non-resettable four-digit timer or fuel meter, purchase records can be used to verify natural gas usage.
[District Rule 204]
4. The owner/operator shall maintain an operations log for this equipment on-site and current for a minimum of two (2) years, and said

Fee Schedule: 2 (c)

Rating: 2500000 Btu

SIC: 3565

SCC: 10200603

Location/UTM(Km):
459E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Storopack Inc.
4758 Devitt Drive
Cincinnati, OH 45246

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

log shall be provided to District personnel on request. The operations log shall include the following information at a minimum:

A. Total operation time (hours per month and an annual total); or,

B. Total fuel consumed on an annual basis.

[District Rule 1302(C)(2)(a)]

5. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]