



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### CANNABIS ODOR COMPLIANCE PLAN AUTHORIZATION

COCPP000005

This California Business & Professions Code Division 10 Compliance Plan (Cannabis Odor Compliance Plan) is authorized in response to District Rule 302(J)(5). This authorization is designed to enforce the provisions of Division 26 of the California Health & Safety Code and applicable District Rules and Regulations. Operations covered by this authorization must be conducted in compliance with all information included with the initial filing and requirements specified below. Equipment referenced by this authorization must be maintained and kept in good operating condition at all times. This authorization shall be maintained on site at the location referenced below at all times.

**EXPIRES LAST DAY OF: JUNE 2024**

#### OWNER OF OPERATOR (Co.#2432)

17K Muskrat 1  
8469 Beach Circle  
Cypress, CA 90630

#### EQUIPMENT LOCATION (Fac.#3829)

17K Muskrat 1  
17080 Muskrat Avenue  
Adelanto, CA 92301

#### Description:

CANNABIS ODOR COMPLIANCE PLAN consisting of: A facility licensed under the Ca Bus. & Prof. Code Division 10 which started operation on 12/20/2019 and includes cannabis cultivation. Odor is controlled by eight Can-Filter Can 150 carbon canisters, 18 Air Filters Inc. Astro-sorb replaceable carbon air filters (venting to atmosphere), and four Ona Gel fluidized absorbers.

#### EQUIPMENT

Capacity	Equipment Description
24600	COCPP Facility Square feet
0	8 Can-Filter Can 150 60" by 16" 123 lb carbon canisters handling 1019 cfm of flow each
0	18 Air Filters Inc. Astro-sorb 20" by 20" by 2" 14 lb carbon filters handling 4000 cfm of flow each and exhausting to atmosphere.
0	Four Ona Gel 12" x 20" 50 lb fluidized adsorbers

#### REQUIREMENTS:

1. The owner/operator shall ensure that this facility does not discharge from any source whatsoever such quantities of odor which cause injury, detriment, nuisance or annoyance to any considerable number of persons or to the public. Compliance with this condition shall be verified by either: (a) no detectable odor at any exterior vent, exterior discharge or exterior container associated with this facility, or

Fee Schedule: 13 (a)

Rating: 1 sq. ft.

SIC: 191

SCC: 30299999

Location/UTM(Km):  
459E/3825N

This plan does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This plan cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This plan must be renewed by the expiration date above. If billing for renewal fee required by Rule 302 is not received by expiration date above, please contact the District.

17K Muskrat 1  
8469 Beach Circle  
Cypress, CA 90630

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

(b) no detectable odor at any portion of the fenceline or property boundary of this facility.