



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

G004951

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2008

OWNER OF OPERATOR (Co.#147)

Circle K Stores, Inc. - Licensing
P.O. Box 52085
Phoenix, AZ 85072

EQUIPMENT LOCATION (Fac.#1681)

Circle K #6017
14511 Palmdale Road
Victorville, CA 92392

Description:

GASOLINE DISPENSING FACILITY consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
001	87U	20,000	Under Ground
002	91U	20,000	Under Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
TPN	12

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	VR-104-A
PII	BAL	G-70-53-AA

CONDITIONS:

1. The toll-free telephone number that must be posted is 1-800-635-4617.

Fee Schedule: 6 (N/A)

Rating: 36 product-nozzles SIC: 5541

SCC: 40600603

Location/UTM(Km):
473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Circle K Stores, Inc. - Licensing
Attn: Environmental

Phoenix, AZ 85072

By: **COPY**

Brad Poiriez

Air Pollution Control Officer

2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

3. Any modifications or changes to the piping or control fittings of the vapor recovery system require prior approval from the District.

4. The vapor vent pipes are to be equipped with pressure relief valves.

5. The owner or operator shall conduct and pass the following tests at least once every three years using the latest adopted version of the following test procedures (next set of testing due in 2008):

- a. Static Torque of Rotatable Phase I Adaptors per TP201.1B
- b. Pressure Decay Test per TP-201.3.
- c. Depending on system configuration, either TP-201-1D, Leak Rate of Drop Tube Overfill Prevention Device and Spill Container Drain Valve; or TP-201.1C, Leak Rate of Drop Tube/Drain Valve Assembly
- d. P/V valves in accord with TP-201.1E.

Passing test report shall be received by the District not later than six (6) weeks prior to the expiration date of this permit in those years when testing is required.

6. The annual throughput of gasoline shall not exceed 6,500,000 gallons per year. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition, a public notice and/or comment period may be required.

7. EVR 2-Point Phase I Vapor Control Equipment to be maintained in Compliance with Executive Order (EO) VR-104-A.

8. Balance Phase II Vapor Control Equipment to be maintained in Compliance with Executive Order G-70-53-AA, nozzles in accord with EO G-70-199, dispensers shall be uni-hose type.

9. In accordance with the EVR timeline for Phase II vapor recovery, the o/o must install EVR Phase II no later than January 2009, and In-Station-Diagnostics (ISD) no later than April 2009.