

**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE**N002573**

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: AUGUST 2013**OWNER OF OPERATOR (Co.#15)**

Pacific Gas & Electric/Air Permits
PO Box 7640
San Francisco, CA 94120

EQUIPMENT LOCATION (Fac.#535)

PG&E - Hinkley Compressor Station
35863 Fairview Road
Hinkley, CA 92347

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
3	87U	2,000	Above Ground
4	Diesel	2,000	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1
Diesel	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-167
PII	BAL	G-70-167

CONDITIONS:

Fee Schedule: 5 (a)

Rating: 2000 gallons

SIC: 4939

SCC: 40600401

Location/UTM(Km):
485E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pacific Gas & Electric/Air Permits
PO Box 7640
San Francisco, CA 94120

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617.
 2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
 3. Any modifications or changes to the piping or control fitting of the vapor recovery system require prior approval from the District.
 4. The vapor vent pipes are to be equipped with pressure relief valves.
 5. The owner or operator shall conduct and pass the following tests annually using the latest adopted version of the following test procedures:
 - a. Pressure Decay Tests per CARB test method TP-201.3B.
 - b. Liquid Removal Test (if applicable) per TP-201.6
 - c. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations.
- The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.
- Passing test reports shall be received by the District not later than six (6) weeks prior to the expiration date of this permit.
6. The annual throughput of gasoline shall not exceed 500,000 gallons per year. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment in accord with a District approved plan. In addition public notice and/or comment period may be required
 7. The o/o shall maintain and operate this equipment in compliance with CARB Executive Order G-70-167.