



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

N008936

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: FEBRUARY 2025

OWNER OF OPERATOR (Co.#1392)

CA DEPT OF CORR & REHAB
P.O. Box C5282
El Centro, CA 92244

EQUIPMENT LOCATION (Fac.#1422)

Chuckawalla Valley State Prison
19025 Wileys Well Road
Blythe, CA 92226

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	15,000	Above Ground
2	Diesel	15,000	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	2
Diesel	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	VR-402
PI	SL	VR-301

Fee Schedule: 5 (b)

Rating: 15000 gallons

SIC: 9223

SCC: 40600603

Location/UTM(Km):
725E/3273N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CA DEPT OF CORR & REHAB
ATTN: Accounts Payable

El Centro, CA 92244

By: **COPY**

Brad Poiriez

Air Pollution Control Officer

CONDITIONS:

1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).
[District Rule 461]
2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
[District Rule 461 - Gasoline Transfer and Dispensing]
3. Any modifications or changes to the piping or control fitting of the vapor recovery system require prior approval from the District.
[District Regulation XIII - NSR]
4. Pursuant to California Health and Safety Code sections 39600, 39601 and 41954, this aboveground tank shall be installed and maintained in accordance with Executive Order (EO) VR-402 for EVR Phase I, and EO VR-302, Standing Loss requirements.
[District Rule 461 and Executive Order VR-402]
5. Pursuant to EO VR-402, vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by the executive order.
[District Rule 461 and Executive Order VR-402]
6. Pursuant to EO VR-402, Maintenance and repair of system components, including removal and installation of such components in the course of any required tests, shall be performed by Morrison Bros. Certified Technicians or as allowed by Executive Officer.
[District Rule 461 and Executive Order VR-402]
7. The owner/operator has elected to operate its fleet with at least 95%+ ORVR vehicles; therefore, this equipment is exempt from Phase II Enhanced Vapor Recovery. To ensure compliance the owner/operator shall keep records of its fleet vehicles, the method by which ORVR is determined, and the percentage of ORVR equipped vehicles, which shall be a minimum of 95%.
[District Rule 204 - Permit Conditions]
8. The Enhanced Vapor Recovery (EVR), Phase I and II Vapor Recovery System must be tested in accordance with the requirements of CARB Executive Orders VR-402, no later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the required test procedures.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdaqmd.ca.gov

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Order VR-402]
9. The annual throughput of gasoline shall not exceed 500,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.
[District Rule 1320 - NSR for Toxic Air Contaminants; District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]
10. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]