



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B008983

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: SEPTEMBER 2007

OWNER OF OPERATOR (Co.#1584)

ComAV Technical Services LLC
18438 Readiness Street
Victorville, CA 92394

EQUIPMENT LOCATION (Fac.#2675)

ComAV Technical Services
18438 Readiness Street
Victorville, CA 92394

Description:

DIESEL IC ENGINE consisting of:

One Hobart Brothers Co - Deutz, Diesel fired internal combustion engine Model No. 90D20PS and Serial No. 395PS01663, Direct Injected, After Cooled, producing 150 bhp with 6 cylinders at 2000 rpm while consuming a maximum of 8.0 gal/hr. This equipment powers a Hobart Brothers Co - Deutz Generator Model No. 90D20P5 and Serial No. 395PS01663, rated at 72 KW.

CONDITIONS:

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. The sulfur concentrations of all diesel fuel used for permitted equipment shall not exceed 0.05% on a weight basis.
3. An operations log shall be maintained on-site for at least two years and be made available to District personnel on request. This log shall contain, as a minimum, the "Hour Meter" reading at the beginning and end of each day, and the total hours operated each day.
4. This I.C. engine equipment shall only be operated/maintained in strict accord with manufacturer's/supplier's recommendations and/or sound engineering principles.
5. This Engine shall not be operated more than 5 hours in any single day.

Fee Schedule: 1 (b)

Rating: 150 bhp

SIC: 4581

SCC: 20200102

Location/UTM(Km):
473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

ComAV Technical Services LLC
18438 Readiness Street
Victorville, CA 92394

By: **COPY**
Brad Poiriez
Air Pollution Control Officer