



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B009607

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 2017**

### **OWNER OF OPERATOR (Co.#84)**

NTC - Public Works  
Bldg 602, 5th Street  
Fort Irwin, CA 92310

### **EQUIPMENT LOCATION (Fac.#3280)**

NTC - Dir. of Public Works, Community Support  
AFZJ-PW-EV, Bldg 602  
Fort Irwin, CA 92310

#### **Description:**

DIESEL IC ENGINE, PORTABLE (BLDG 367) consisting of: Year of Manufacture - 2001; Tier 1; CARB EO U-R-2-72; Engine Family 1CEXL03.3AAA

One Cummins, Diesel fired internal combustion engine Model No. 4045 and Serial No. 4045D96798, producing 78 bhp with 4 cylinders at 2200 rpm while consuming a maximum of 3.0 gal/hr. This equipment powers a Sullair Compressor Model No. 185DPQJD and Serial No. 004-133346, rated at 58 kw.

#### **EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	5.0	gm/bhp-hr
HC	5.0	gm/bhp-hr
NOx	7.6	gm/bhp-hr
PM10	0.06	gm/bhp-hr
SOx	0.2	gm/bhp-hr
VOC	5.0	gm/bhp-hr

#### **CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [Rule 204]

Fee Schedule: 1 (b)

Rating: 78 bhp

SIC: 9711

SCC: 20100102

Location/UTM(Km):  
511E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works  
Attn: Air Resources Manager  
  
Fort Irwin, CA 92310

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

2. This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. (This system must be moved within this facility or moved to another facility annually.) [Title 17 CCR 93116.2(bb)]

3. This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15) on a weight per weight basis per CARB Diesel or equivalent requirements. [17 CCR 93116]

4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time. [Title 17 CCR 93116]

5. The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
  - b. Reason for use (Regular use, testing & maintenance, emergency, required emission testing);
  - c. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
  - d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).
- [Rule 204; Title 17 CCR 93116]

6. The fleet\* under control of this o/o is subject to and shall comply with the weighted Diesel Particulate Matter (DPM) emission fleet averages\*\* expressed as grams per brake horsepower-hour (g/bhp-hr) of Title 17 CCR Section 93116.3(c) & (d) by the following dates:

Compliance Date Weighted DPM (g/bhp-hr)

January 1, 2013 0.30

January 1, 2017 0.18

January 1, 2020 0.04

\* Fleet is defined in Title 17 CCR Section 93116.2(p) as one or more portable unit(s).

\*\* The method used to calculate the Fleet Average is found in Title 17 CCR 93116.3(d).

7. The o/o of this unit must submit a Statement of Compliance signed by the Responsible Official that the fleet standards are being achieved and a summary that identifies each portable engine in the fleet and the associated emission rate (g/bhp-hr) and other required information, see Title 17 CCR 93116.4(e)(2), (3), (4), (5), (6) and (7) for the following compliance statement submittal dates:

Weighted DPM Emission Fleet Average Date Submit by

January 1, 2013 March 1, 2013

January 1, 2017 March 1, 2017

January 1, 2020 March 1, 2020

8. The o/o of fleets that are exempted from the requirements of section 93116.4 pursuant to section 93116.4 (a), the Responsible Official shall certify that all portable diesel-fueled engines in the fleet satisfy the requirements of section 93116.4(a). See Title 17 CCR 93116.4(f) for details. [Rule 204]

9. This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Portable Compression Ignition Engines (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the requirements of the ATCM shall govern. [Rule 204]

10. This engine shall not operate more than 18 hours in any single day, defined as any consecutive 24 hour period. [Rule 1303, Rule 204]

11. This facility shall emit less than the following on a calendar year basis;

Oxides of Nitrogen (NOx) - 25 tons,

Volatile Organic Compound (VOC) - 25 tons,

Particulate Matter less than 10 microns (PM10) - 15 tons, and

Hazardous Air Pollutants (HAP) - 10 tons per year for any single HAP and 25 tons per year for any combination of HAPs. Compliance shall be demonstrated annually to the District through the submission of a District approved Comprehensive Emission Inventory Report (CEIR) or other District approved equivalent method. The report shall be submitted to the District no later than April 30 of each year.