



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

B010504

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: AUGUST 2024

OWNER OF OPERATOR (Co.#15)

Pacific Gas & Electric/Air Permits
PO Box 7640
San Francisco, CA 94120

EQUIPMENT LOCATION (Fac.#39)

PG&E - Topock Compressor Station
145453 National Trails Highway
Needles, CA 92363

Description:

ODORIZATION SYSTEM, LINE 300A consisting of: 40' by 8.5' by 8' H skid-mounted OdorEyes Accu/Line Injection Odorizer operating at a nominal 0.25 to 0.35 pounds/MMscf injection rate, with a 5000 gallon horizontal odorant tank and related ancillary equipment. Injects odorant into natural gas transmission lines.

EQUIPMENT

Capacity	Equipment Description
5	Odorant storage tank, aboveground (5000 gallon capacity)
0	Injection, metering and control equipment

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. The owner/operator (o/o) shall operate this equipment in strict accord with manufacturer's specification and/or sound engineering principles.

Fee Schedule: 5 (a)

Rating: 5000 gallons

SIC: 4939

SCC: 99999999

Location/UTM(Km):
730E/3844N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pacific Gas & Electric/Air Permits
PO Box 7640
San Francisco, CA 94120

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

3. The o/o shall continuously monitor this system for leaks and comply with District Rule 430, Breakdown Provisions.