



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B013100

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2019

OWNER OF OPERATOR (Co.#2855)

West Coast Aggregate Supply, Inc.
119278 North Cadiz Road
Twentynine Palms, CA 92277

EQUIPMENT LOCATION (Fac.#3790)

West Coast Aggregate Supply, Inc.
119278 North Cadiz Road
Twentynine Palms, CA 92277

Description:

DIESEL IC ENGINE, PORTABLE GENERATOR consisting of: Model Year 2001, US EPA Engine Family 1CEXL0239ABA, Tier 1.

One Cummins, Diesel fired internal combustion engine Model No. 4BT3.9-G4 and Serial No. 46081720, After Cooled, Turbo Charged, producing 102 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 5.8 gal/hr. This equipment powers a TBD Generator Model No. TBD and Serial No. TBD, rated at 76 kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	2.63	gm/bhp-hr
NOx	6.15	gm/bhp-hr
PM10	0.87	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.97	gm/bhp-hr

CONDITIONS:

1. This portable Tier 1 compression-ignited internal combustion engine shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 204]

Fee Schedule: 1 (b)

Rating: 102 bhp

SIC: 1479

SCC: 20100102

Location/UTM(Km): 679E/3783N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

West Coast Aggregate Supply, Inc.
P.O. Box 790
Thermal, CA 92274-0790

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

2.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.
[Title 17 CCR 93116.4(c)(2)(A)]

3.This unit cannot operate in the State of California after January 1, 2020.
[District Rule 204]

4.This engine shall not operate for more than 1920 hours per year (12 consecutive months).
[District Rule 1303]

5.This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days.
(This system must be moved for a valid business purpose within this facility or moved to another facility annually.)
[Title 17 CCR 93116.2(bb)]

6.This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) per CARB Diesel or equivalent requirements; or alternative diesel fuel or CARB diesel fuel utilizing fuel additives that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines.
Note: Use of CARB ULSD satisfies this requirement.
[Title 17 CCR 93116.3(a)]

7.The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
 - b. Reason for use (Regular use, testing & maintenance, emergency, required emission testing);
 - c. Monthly and annual operation in terms of fuel consumption (in gallons) and total hours; and,
 - d. Fuel sulfur concentration (the owner/operator may use the supplier's certification of sulfur content if it is maintained as part of this log).
 - f. Location of operation, in latitude/longitude, accurate to 5 decimal places.
- [District Rule 1302; 1320; Title 17 CCR 93116.4(c)]

8.This engine is subject to the requirements of Title 17 CCR 93116, the Airborne Toxic Control Measure (ATCM) for Diesel Particulate Matter from Portable Engines Rated at 50 Horsepower and Greater. In the event of a conflict between these conditions and the ATCM or NSPS, the more stringent requirements shall govern.
[District Rule 1302; Title 17 CCR 93116]

9.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]