



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C007438

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MAY 2023

OWNER OF OPERATOR (Co.#2239)

CalPortland Company
19409 National Trails Hwy
Oro Grande, CA 92368

EQUIPMENT LOCATION (Fac.#3)

CalPortland Oro Grande
19409 National Trails Hwy
Oro Grande, CA 92368

Description:

SULFUR REDUCTION DEVICE (431SS1) consisting of: designed to reduce SOx in raw mill/kiln stream; design parameters to be determined

CONDITIONS:

1. The owner/operator, o/o, shall install, operate and maintain this sulfur oxides reduction device in strict accord with those recommendations of the manufacturer/supplier.
2. The o/o shall institute a program of maintenance, which shall be determined subsequent to final design configurations. These final design configurations shall be submitted to the District within 90 days of the issuing of the complete letter.
3. The o/o shall log all the items in 2 above in addition to bag replacements, repairs and non-scheduled maintenance. The log shall be kept current, on-site for a minimum of 5 years and provided to District personnel on request.
4. This equipment shall operate concurrently with the Kiln and/or Raw Mill Grinding System under valid District permit numbers B007435 and B007439.
5. This equipment shall discharge no more than 780 lb of sulfur oxides/day (calculated as sulfur dioxide), based on the operating conditions described above.
6. Within 180 days from the initial start-up of this unit, the o/o shall conduct emissions testing in strict accord with all procedures

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 3241

SCC: 99999999

Location/UTM(Km): 469E/3830N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CalPortland Company
Attn: Catalina Elias

Oro Grande, CA 92368

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

described in the District's Compliance Test Procedural Manual. This testing is necessary to demonstrate compliance with permit conditions in 7 above and District Rule 406. The District shall be notified no less than 10 working days prior to the test and receive the final test report of emissions no later than 45 days subsequent to the final day of on-site sampling/measurements.