



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

E003844

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 2003**

### **OWNER OF OPERATOR (Co.#87)**

Commanding Officer, MCLB Barstow, CA  
Box 110570 Bldg 196 Attn: Air Program Manager  
Barstow, CA 92311-5050

### **EQUIPMENT LOCATION (Fac.#1177)**

USMC MCLB - Nebo Annex  
USMC Logistics Base  
Barstow, CA 92311-5013

#### **Description:**

EMERGENCY INTERNAL COMBUSTION ENGINE @ BLDG 322, portable - various locations on base, consisting of:

One Perkins, Diesel fired internal combustion engine Model No. CVM 8203-8 and Serial No. 389205, producing 600 bhp with 8 cylinders at 1800 rpm while consuming a maximum of. This equipment powers a Leroy Somer 350 kW Generator Model No. LSA 49L5 and Serial No. 153409/1, rated at.

#### **CONDITIONS:**

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants.
3. This unit shall be limited to use for emergency power, defined as when commercially available power has been interrupted, and as part of a testing program which does not exceed 60 minutes of operation per week.
4. The owner/operator (o/o) shall use only diesel fuel whose sulfur concentration is less than or equal to 0.05% on a weight per weight basis in this unit.
5. The o/o shall maintain a log for this unit, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:

Fee Schedule: 7 (g)      Rating: 1 device      SIC: 9711      SCC: 20100102      Location/UTM(Km): 505E/3859N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Commanding Officer, MCLB Barstow, CA  
Box 110570 Attn: Air Program Manager  
Barstow, CA 92311-5050

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

- a. Date of each use;
- b. Duration of each use, in minutes;
- c. Fuel consumed during each calendar year, in gallons;
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).