



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E010118

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: FEBRUARY 2014

OWNER OF OPERATOR (Co.#2349)

MP Mine Operations LLC
67750 Bailey Road
Mountain Pass, CA 92366

EQUIPMENT LOCATION (Fac.#364)

Mountain Pass Mine
67750 Bailey Road
Mountain Pass, CA 92366

Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR (GND-2) consisting of: Yr of Mfg1987, Tier 0

One Cummins, Diesel fired internal combustion engine Model No. 4BT-3.9 and Serial No. 44236170, Other, Other, producing 86 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 2.0 gal/hr. This equipment powers a United States Motors Corp Generator Model No. S15D18 and Serial No. 341042, rated at 15 kw.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	7.21	gm/bhp-hr
HC	2.08	gm/bhp-hr
NOx	18.13	gm/bhp-hr
PM10	0.93	gm/bhp-hr
VOC	2.08	gm/bhp-hr

CONDITIONS:

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 1099

SCC: 20100102

Location/UTM(Km):
634E/3926N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MP Mine Operations LLC
1700 S. Pavilion Center Drive, 8th Floor
Las Vegas, NV 89135

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

1. The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of two (2) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

2. This unit shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

3. This genset is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines (Title 17 CCR 93115). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern.

4. This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15ppm) on a weight per weight basis per CARB Diesel or equivalent requirements.

5. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

6. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

7. This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 20 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 20 hour per year limit.

8. Mountain Pass Mine Voluntary Emissions Limit/Synthetic Minor Hazardous Air Pollutant Limits:

(a). General Limits for Entire Facility. The total emissions for the Mountain Pass Mine shall be less than 25 tons per year of VOC. The total emissions of Hazardous Air Pollutants (HAPs) for the Mountain Pass Mine shall not exceed 7 tons per year for any single HAP and 18 tons per year for any combination of HAPs calculated on an annual basis. HAPs are defined in 40 CFR 61.01 Lists of pollutants and are the chemical compounds listed in section 112(b) of the Clean Air Act (Act).

(b). Monitoring, Periodic Monitoring & Recordkeeping Conditions. To prove compliance with condition (a) above, permittee shall maintain usage records of all VOC- and HAP-containing solvent materials. Such records shall be compiled into an annual usage report and total HAP emissions from solvent operations shall be added to the annual HAP emissions from fuel burning and other HAP emitting equipment. Annual HAP/VOC emissions from fuel burning and other emitting equipment for purposes of this condition shall be determined by use of HAP/VOC emissions factors (as set forth by District approved emission factors), or by annual actual emissions as determined by source test of the equipment, or by methods and emission factors established in an approved comprehensive Emission Inventory Plan (CEIP).

[40 CFR 70.6 (a)(3)(i)(B) - Periodic Monitoring Requirements]

[Rule 204 - Permit Conditions; Version in SIP = CARB Ex. Order G-73, 40 CFR 52.220(c)(39)(ii)(B) - 11/09/78 43 FR 52237; Current Rule Version = 07/25/77]

[California Clean Air Act, Health and Safety Code \S\S39607 and \S\S44300 et seq., and the Federal Clean Air Act, \S110(a)(2)(F)(ii), codified in 40 CFR 60 Subpart Q]