



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### PERMIT TO OPERATE

T003303

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: AUGUST 2024**

#### **OWNER OF OPERATOR (Co.#15)**

Pacific Gas & Electric/Air Permits  
PO Box 7640  
San Francisco, CA 94120

#### **EQUIPMENT LOCATION (Fac.#39)**

PG&E - Topock Compressor Station  
145453 National Trails Highway  
Needles, CA 92363

#### **Description:**

TANK, WASTE OIL STORAGE consisting of: Welded steel 7,150 gal cylindrical fixed roof tank 8 ft in diameter and 20 ft high

#### **CONDITIONS:**

1. This tank is limited to storing waste oil generated on-site by Pacific Gas & Electric.
2. All flanges, seals, pumps and other appurtenant equipment shall be installed and maintained to prevent the loss of volatile fractions.
3. The owner/operator (o/o) shall log all shipments of oil to other parties and the hauler of said oil. Additionally, this log shall contain the mass (or volume) and the date of the oil shipment.
4. The o/o shall keep the log on-site for a minimum of five (5) years and provide it to District personnel on request.

Fee Schedule: 5 (a)

Rating: 7150 gallons

SIC: 4939

SCC: 99999999

Location/UTM(Km):  
730E/3844N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pacific Gas & Electric/Air Permits  
PO Box 7640  
San Francisco, CA 94120

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer