

MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310 760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B004157

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: OCTOBER 2004

OWNER OF OPERATOR (Co.#31)

Southern California Gas Co. - MD 9400 Oakdale Avenue Chatsworth, CA 91313

EQUIPMENT LOCATION (Fac.#1437)

SCG - Blythe 13100 W 14th Avenue Blythe, CA 92225

Description:

INTERNAL COMBUSTION ENGINE (PLT #1, AUXILIARY BLDG) consisting of: INTERNAL COMBUSTION ENGINE

One Ingersoll Rand, NG fired internal combustion engine Model No. PVG and Serial No. 8HP2568, producing 370 bhp with 8 cylinders at 1800 rpm while consuming a maximum of . This equipment powers a Model No. and Serial No. , rated at .

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

2. This equipment shall be properly maintained and kept in good operating condition at all times.

3. The owner/operator of this equipment shall comply with all applicable District Rules and Regulations.

Fee Schedule: 1 (c)

Rating: 370 bhp

SIC: 4922

SCC: 99999999

Location/UTM(Km): 719E/3271N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Gas Co. - MD PO Box 2300, SC 9314 Chatsworth, CA 91313-2300



Brad Poiriez Air Pollution Control Officer