



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B005174

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2004

OWNER OF OPERATOR (Co.#87)

Commanding Officer, MCLB Barstow, CA
Box 110570 Bldg 196 Attn: Air Program Manager
Barstow, CA 92311-5050

EQUIPMENT LOCATION (Fac.#1177)

USMC MCLB - Nebo Annex
USMC Logistics Base
Barstow, CA 923115013

Description:

50 HP STEAM BOILER-No. 1 (Bldg 353) consisting of: a Parker Boiler, model 50L, Serial No 39361 This boiler is rated at 50 boiler hp which is equivalent to 2.09 million Btu/h input. This unit is equipped to fire pipeline regulated natural gas through a pre-mix LoNOx burner system.

CONDITIONS:

1. The owner, o/o, shall install, operate and maintain this boiler in strict accord with the provisions of the entire submittal with the application for this permit. The submittal is incorporated in its entirety as an integral part of these conditions to operate and they act as specific limitations unless specifically exempted hereunder.
2. The o/o shall not use any other fuel in this boiler but California Public Utility regulated pipeline natural gas without the prior written approval of the District APCO.
3. The o/o shall log the volume of natural gas to this boiler on a calendar monthly basis. The log shall be maintained current, on-site for a minimum of 2 years and provided to District personnel on request.

Fee Schedule: 2 (c)

Rating: 2090000 Btu

SIC: 9711

SCC: 99999999

Location/UTM(Km):
505E/3859N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Commanding Officer, MCLB Barstow, CA
Box 110570 Attn: Air Program Manager
Barstow, CA 92311-5050

By: **COPY**
Brad Poiriez
Air Pollution Control Officer