



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

**B009545**

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 2014**

### **OWNER OF OPERATOR (Co.#87)**

Commanding Officer, MCLB Barstow, CA  
Box 110570 Bldg 196 Attn: Air Program Manager  
Barstow, CA 92311-5050

### **EQUIPMENT LOCATION (Fac.#587)**

USMC MCLB - Yermo Annex  
USMC Logistics Base  
Barstow, CA 923115013

#### **Description:**

PORTABLE DIESEL IC ENGINE, EXCAVATOR @ BLDG 614; This is a Low Use Engine; Shall Not Exceed 80 hours consisting of: unit may be operated at both the Yermo and Nebo Annexes, Year of Manufacture - 1998

One Cummins, Diesel fired internal combustion engine Model No. B5.9-C and Serial No. 45641308, Turbo Charged, After Cooled, producing 148 bhp with 4 cylinders at 2200 rpm while consuming a maximum of 56.0 lbs/hr. This equipment powers a Gradall Generator Model No. XL 4100 and Serial No. 0419278, rated at NULL.

#### **EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
NOx	14.9	gm/bhp-hr

#### **CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
2. This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. (This system must be moved within this facility or moved to another facility annually.) [Title 17 CCR 93116.2(bb)]
3. This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% or 15 ppm per CARB Diesel or equivalent requirements; or alternative diesel fuel or CARB diesel fuel utilizing fuel additives that has been verified

Fee Schedule: 1 (b)

Rating: 148 bhp

SIC: 9711

SCC: 20200102

Location/UTM(Km):  
512E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Commanding Officer, MCLB Barstow, CA  
Box 110570 Attn: Air Program Manager  
Barstow, CA 92311-5050

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines. [Title 17 CCR 93116.3(a)]

4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time by January 1, 2012. [Title 17 CCR 93116.4(c)(2)(A)]

5. This portable diesel fueled engine (unit) shall be certified to meet a federal or California standard for newly manufactured nonroad engines pursuant to 40 CFR Part 89, Part 86, or the equivalent categories in Title 13 of the California Code of Regulations (CCR). Otherwise, use this portable diesel-fueled engines exclusively in emergency applications or portable diesel-fueled engines that qualify as low-use engines (operates 80 hours or less per year) and commit by December 31, 2011 to removing these engines from service or replacing these engines no later than January 1, 2017. The replacement engines shall be certified to the most stringent of either the federal or California emission standards for the appropriate class and category of nonroad engine in effect at the time of the replacement. [Title 17 CCR 93116.3(b)]  
[Rule 204 - Permit Conditions; Version in SIP = CARB Ex. Order G-73, 40 CFR 52.220(c)(39)(ii)(B) -11/09/78 - 43 FR 52237; Current Rule Version = 07/25/77]

6. The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (Regular use, testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log). [Title 13 CCR 93116.4(c)]

7. The fleet under control of this o/o is subject to and shall comply with the weighted PM emission fleet averages expressed as grams per brake horsepower-hour (g/bhp-hr) by the listed compliance dates in Title 17 CCR Section 93116.3(c).

Fleet Standard Compliance;

Date	Engines <175 bhp	Engines >175 to 749 bhp	Engines >750 bhp
	(g/bhp-hr)	(g/bhp-hr)	(g/bhp-hr)
1/1/2013	0.3	0.15	0.25
1/1/2017	0.18	0.08	0.08
1/1/2020	0.04	0.02	0.02

See 17 CCR Section 93116.2 for definition of fleet. Engines designated as low use or emergency are not subject to the fleet requirements (93116.3 (c)(3)).

[Title 17 Section 93116.3 - Requirements]

[Rule 204 - Permit Conditions; Version in SIP = CARB Ex. Order G-73, 40 CFR 52.220(c)(39)(ii)(B) -11/09/78 - 43 FR 52237; Current Rule Version = 07/25/77]

8. The o/o of this unit must submit a Statement of Compliance signed by the Responsible Official that the fleet standards are being achieved and a summary that identifies each portable engine in the fleet and the associated emission rate (g/bhp-hr) and other required information, see Title 17 CCR 93116.4(e)(2), (3), (4), (5), (6) and (7) for the following compliance statement submittal dates:

Weighted DPM Emission Fleet Average Date Submit by

January 1, 2013 March 1, 2013

January 1, 2017 March 1, 2017

January 1, 2020 March 1, 2020

9. The o/o of fleets that are exempted from the requirements of section 93116.4 pursuant to section 93116.4 (a), the Responsible Official shall certify that all portable diesel-fueled engines in the fleet satisfy the requirements of section 93116.4(a). See Title 17 CCR 93116.4(f) for details.

10. This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Portable Compression Ignition Engines (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern.

11. This portable equipment shall not be operated and/or located within 1,000 feet of a public or private school (kindergarten through 12th grade) of more than 12 students for more than 45 consecutive days without completing the notification required by Health and Safety Code \S\S 42301.6.  
[Rule 204 - Permit Conditions; Version in SIP = CARB Ex. Order G-73, 40 CFR 52.220(c)(39)(ii)(B) -11/09/78 - 43 FR 52237; Current Rule Version = 07/25/77]

12. This portable compressor and Diesel fuel ICE can be used at all facilities owned or operated by USMC Logistics Base Barstow within the MDAQMD, to include but not limited to the Yermo Annex and Nebo Annex.