



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B013233

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JULY 2019

OWNER OF OPERATOR (Co.#2222)

Palmdale Energy, LLC
801 2nd Avenue
Seattle, WA 98104

EQUIPMENT LOCATION (Fac.#3582)

Palmdale Energy LLC
950 East Avenue M
Palmdale, CA 93550

Description:

HRSG DUCT BURNER #2 consisting of: a Heat Recovery Steam Generator Manufactured by Siemens, Fired on Natural Gas and having a maximum heat input rating 193.1 MMBtu/hr.

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

[Rule 204]

2. This equipment shall be exclusively fueled with pipeline quality natural gas and shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.

[Rule 431.1; Rule 1303]

3. The duct burner shall not be operated unless the combustion turbine generator with valid District permit B013231, catalytic oxidation system with valid District permit C013235, and selective catalytic NOx reduction system with valid District permit C013237, are in operation.

[Rule 1303]

4. This equipment shall not be operated for more than 1500 hours per rolling twelve-month period.

[Rule 1303]

5. Monthly hours of operation for this equipment shall be recorded and maintained on site for a minimum of five (5) years and shall be

Fee Schedule: K2 (N/A)

Rating: 193100000 Btu

SIC: 491

SCC: 20200201

Location/UTM(Km):
425E/3830N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Palmdale Energy, LLC
801 2nd Avenue

Seattle, WA 98104

By: **COPY**

Brad Poiriez

Air Pollution Control Officer

provided to District personnel on request.
[Rule 1303]?