

## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310 760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### **INACTIVE**

B013262

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: JUNE 2020** 

# OWNER OF OPERATOR (Co.#2073)

EQUIPMENT LOCATION (Fac. #3871)

Cutting Edge Agregates, Inc. 18020 National Trails Highway Oro Grande, CA 92307 Cutting Edge Aggregates DBA Owl Rock Products 24724 Quarry Road Apple Valley, CA 92307

# **Description:**

DIESEL IC ENGINE, PORTABLE GENERATOR consisting of: A certified Tier 2 diesel engine, EPA Family 5CPXL58.6ERK, manufactured in 2005, with no after-exhaust emission control devices other than a Smoke Puff Limiter installed. Exhaust flow is approximately 11248 ACFM at 891 degrees Fahrenheit:

One Caterpillar, Diesel fired internal combustion engine Model No. 3512B and Serial No. 1GZ04155, Direct Injected, Turbo Charged, Smoke Puff Limiter, Electronic Control Module, Compression-Ignited, Charge Air Cooler, producing 2172 bhp with 12 cylinders at 1800 rpm while consuming a maximum of 101.9 gal/hr. This equipment powers a Caterpillar Generator Model No. XQ 1500 and Serial No. TBD, rated at 1500 kW(e).

#### **EMISSIONS RATES**

| Emission Type | Est. Max Load | Unit      |
|---------------|---------------|-----------|
| СО            | 1.04          | gm/bhp-hr |
| NOx           | 6.24          | gm/bhp-hr |
| PM10          | 0.134         | gm/bhp-hr |
| PM2.5         | 0.134         | gm/bhp-hr |
| SOx           | 0.0046        | gm/bhp-hr |
| VOC           | 0.30          | gm/bhp-hr |

#### **CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

Fee Schedule: 1 (d)

Rating: 2172 bhp

SIC: 1499

SCC: 20100102

Location/UTM(Km): 488E/3830N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Cutting Edge Agregates, Inc. PO Box 398 Oro Grande, CA 92368

By: COPY

Brad Poiriez
Air Pollution Control Officer

Page 1 of 2 Permit: B013262 Issue Date: 04/22/2020

- 2. This diesel IC Engine and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. (This system must be moved for a valid business purpose at least once each year). [Title 17 CCR 93116.2(bb)]
- 3. This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) per CARB Diesel or equivalent requirements; or alternative diesel fuel or CARB diesel fuel utilizing fuel additives that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines.

  Note: Use of CARB certified ULSD satisfies this requirement.

  [Title 17 CCR 93116.3(a)]
- 4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time. [Title 17 CCR 93116.4(c)(2)(A)]
- 5. A dedicated, calibrated, and non-resettable fuel meter shall be installed and maintained on this unit to precisely indicate cumulative fuel usage.

[District Rules 204 and 1303]

- 6. This engine and the engine described in District Permit B013561 shall not consume more than 161,500 gallons of ULSD in any consecutive 12 month period while collocated at the same facility.

  [District Regulation XII, District Rules 1303 and 1320]
- 7. This engine shall not operate within 1000 meters of any offsite receptor without prior written authorization of the District. [District Rule 1320]
- 8. This engine shall not operate past January 1st, 2025. [Title 17 CCR 93116.3.(c)]
- 9. The owner/operator must maintain an operations log for this unit, current and on-site (or at a central location), for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:
- a. Date and location (in xx.xxxx degrees Latitude and -yyy.yyyy degrees Longitude format) each time the unit is moved;
- b. Hour meter readings totaled on a monthly basis and for each twelve month period;
- c. Fuel meter readings totaled on a monthly basis and for each twelve month period; and,
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log). [Title 17 CCR 93116.4(c)]
- 10. This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Portable Compression Ignition Engines (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern. [District Rule 1302]
- 11. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

  [District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]

Page 2 of 2 Permit: B013262 Issue Date: 04/22/2020