



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

AUTHORITY TO CONSTRUCT

B013564

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

EXPIRES LAST DAY OF: JUNE 2024

OWNER OF OPERATOR (Co.#681)

General Atomics - LSNC
3550 General Atomics Court
San Diego, CA 92121-1194

EQUIPMENT LOCATION (Fac.#3950)

G A Aeronautical Sys - SCLA
18654 Readiness Street
Victorville, CA 92392

Description:

DIESEL IC ENGINE, GENERATOR* (UNIT ID 25) consisting of: A certified Tier 4 final diesel engine, USEPA Family JCEXL04.5AAH, manufactured in 2018 and equipped with factory-installed emission controls. Exhaust flow is 602 acfm at 778 degrees Fahrenheit through a 5.375 foot tall by 3 inch diameter stack. *Please note, this equipment may be operated at various locations at this facility, however emissions comply with the requirements of 17 CCR 93115 and 40 CFR 60, Subpart IIII.

One Cummins, Diesel fired internal combustion engine Model No. QSB4.5 and Serial No. 74307644, Direct Injected, Turbo Charged, Inter Cooled, Selective Catalytic Reduction, Exhaust Gas Recirculation, Exhaust Gas Recirculation, Diesel Oxidation Catalyst, Electronic Control Module, Selective Catalytic Reduction, Charge Air Cooler, producing 155 bhp with 4 cylinders at 2000 rpm while consuming a maximum of 7.46 gal/hr. This equipment powers a Hobart Ground Power Unit Model No. TBD and Serial No. 318PS22651, rated at 116 kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.030	gm/bhp-hr
NOx	0.075	gm/bhp-hr
PM10	0.015	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.030	gm/bhp-hr

CONDITIONS:

Fee Schedule: 1 (b)

Rating: 155 bhp

SIC: 3721

SCC: 20100102

Location/UTM(Km):
465E/3827N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

General Atomics - LSNC
ATTN: LSNC

San Diego, CA 92186-5608

By: **COPY**

Brad Poiriez

Air Pollution Control Officer

1. This certified stationary compression-ignited internal combustion engine and its associated emission control systems shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 1302; 40 CFR 60.4211(a)]

2. This engine shall not be operated unless all of the following emission control systems are properly functioning:

- a. Diesel Oxidation Catalyst
- b. Electronic Control Module
- c. Exhaust Gas Recirculation System
- d. SCR
- e. Diesel Oxidation Catalyst

Furthermore, no changes shall be made to any of the above systems unless done so by a factory certified technician.

[District Rule 1302; 40 CFR 60.4211]

3. This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

- a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,
- b. A cetane index or aromatic content, as follows:
 - 1. A minimum cetane index of 40; or,
 - 2. A maximum aromatic content of 35 volume percent.

[17 CCR 93115.5(a); 40 CFR 80.510(b)]

Note: Use of CARB certified ULSD fuel satisfies the above requirements.

4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

[Title 17 CCR 93115.10(d)]

5. This engine shall not operate for more than 1,000 hours in any consecutive 12 month period.

[District Rules 1302, 1303, and 1320]

6. The owner/operator must conduct an inspection, whichever is more frequent of, at least once every calendar quarter; or, after every 2,000 hours of engine operation. An inspection includes any testing, maintenance, and/or other procedures that ensure the Internal Combustion Engine is operated in strict accordance with the manufacturer's specifications and in continual compliance with the provisions of this rule.

[District Rule 1160]

7. The owner/operator shall maintain an operations log for this unit, current and on-site (or at a central location), for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Monthly and consecutive 12 month period hour meter readings, including the dates of all monthly readings;
- b. Date of each maintenance action or repair on any equipment noted in Condition #2;
- c. Description of each maintenance action or repair on any equipment noted in Condition #2;
- d. Fuel sulfur concentration as required by condition #3 (you may use the supplier's certification of sulfur content if it is maintained as part of this log);
- e. Calendar year operating hours as determined by the installed hour meter (to assist in CEI calculations); and
- f. Results of any source testing conducted on the engine.

[District Rules 1160, 1302 and 1320; 17 CCR 93115]

8. This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (NSPS). In the event of a conflict between these conditions and the ATCM or NSPS, the more stringent requirements shall govern.

[District Rule 1302]

9. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the

District, in a format approved by the District, upon District request.
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]