



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

RENEWAL

C013153

Renewal type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2025

OWNER OF OPERATOR (Co.#2448)

EPOD Holdings, LLC
9381 Commerce Way, Unit D
Adelanto, CA 92301

EQUIPMENT LOCATION (Fac.#3842)

EPOD Holdings, LLC
9381 Commerce Way, Unit D
Adelanto, CA 92301

Description:

ODOR CONTROL SYSTEM, CANNABIS EXTRACTION, UNPACKAGING, AND POST-PROCESS consisting of: An explosion proof booth classified as Class 1, Division 1, spark free, with large and rapid air exchange rates. Booth contains the extraction equipment. Booth is equipped with a 1/2 hp exhaust fan generating TBD scfm and vents outside the building through TBD 250 (TM) high efficiency carbon/particulate exhaust filters.

CONDITIONS:

1. These air pollution control devices shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 204]

2. This facility shall notify the District within thirty days of permit issuance to schedule an initial inspection. Email notification shall be sent to engineering@mdaqmd.ca.gov. [District Rule 1302]

3. The filters used in these Air Filtration Systems shall have the manufacturer's recommended prefilters properly installed whenever the system is in operation. [District Rule 1302]

4. Odors from this equipment shall be non-detectable and the activated carbon filters must be changed any time breakthrough has occurred. The owner/operator shall conduct quarterly odor detection checks at the exhaust of the above described equipment to ensure that breakthrough has not occurred. If odors are detected, the filters must be changed immediately. If the exhaust of this equipment is

Fee Schedule: 7 (h) Rating: 1 device SIC: 2833 SCC: 30299998 Location/UTM(Km): 459E/3825N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

EPOD Holdings, LLC
9420 Reseda Blvd. #406
Northridge, CA 91324

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

not accessible, then the filters must be replaced every quarter.
[District Rules 204 and 402]

5.The owner/operator must take all steps necessary to preclude odor migration from this facility, including but not limited to, carbon filter change outs when breakthrough has occurred, keeping doors and windows closed to the maximum extent possible, isolating odor-emitting activities from other areas of the buildings through closing doors and windows, and operating all air filters continuously during cultivation activities.

[District Rule 402]

6.A log pertaining to the operation of this equipment shall be kept for a period of two (2) years, and must be made available upon request of District personnel. This log shall contain, as a minimum, the following information:

- a. The date and time of each activated carbon filter replacement;
- b. Results of quarterly odor monitoring checks; and
- c. A copy of the manufacturer's specification for control efficiency for the activated carbon filters.

[District Rule 204]

7.The o/o shall maintain on-site a minimum inventory of replacement filters that assures compliance with these conditions.

[District Rules 204 and 402]

8.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]