



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E003769

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2000

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#589)

NTC - Dir. of Public Works, Mission Related
Bldg. 602, 5th street
Fort Irwin, CA 923105085

Description:

IC ENGINE, EMERGENCY GENERATOR (TIEFORD MOUNTAIN UTM 405044) consisting of:

One Doutz, Diesel fired internal combustion engine Model No. BF6L413/F and Serial No. 5953210, producing 136 bhp with cylinders at rpm while consuming a maximum of . This equipment powers a Kato Generator Model No. 755X9E and Serial No. 81614-2, rated at 75 kW.

CONDITIONS:

1. This I.C. Engine equipment shall be operated/maintained in strict accord with manufacturer's/supplier's recommendations and/or sound engineering principles.
2. This I.C. Engine shall only be operated when utility power (line power) is not available due to a power outage and no more than two and one half (2.5) hours in any one day and in any one week for testing.
3. This I.C. Engine shall only burn number 2 fuel oil and/or JP-8.
4. The fuel burned in this I.C. Engine shall contain sulfur equal to or less than 0.05% by weight.
5. The owner/operator (o/o) shall require from their supplier analytical results relating to the sulfur content of the fuel delivered and shall not accept delivery whenever the sulfur concentration exceeds 0.05% by weight.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 9711

SCC: 20100102

Location/UTM(Km):
529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA 92310

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

6. The o/o shall maintain copies of these delivery results on-site and provide them to District personnel on request.
7. An operations log shall be maintained on-site for at least two (2) years and be made available to District personnel on request. This log shall contain, as a minimum, the "Hour Meter" reading at the beginning and end of each day; the total hours operated each day; amount of fuel burned each month; and amount and sulfur content of all fuel deliveries.
8. The o/o shall comply with all applicable rules and regulations of the District. Applicable rules include, but are not necessarily limited to Regulation IV.