



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

N012487

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: FEBRUARY 2025

OWNER OF OPERATOR (Co.#2260)

Freeman Holding of CA, L.L.C.
18590 Readiness St.
Victorville, CA 92394

EQUIPMENT LOCATION (Fac.#3623)

Million Air Victorville
18590 Readiness St.
Victorville, CA 92394

Description:

AVIATION STORAGE AND DISPENSING (AVGAS TRUCK) consisting of: Model Year TBD Isuzu NPR HD Tank Truck with a 1000 gallon capacity.

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	AvG	1,000	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
AvG	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
------	----------------	------------

CONDITIONS:

1. This equipment, shall be installed, operated, and maintained in strict accord with those recommendations of the

Fee Schedule: 5 (a)

Rating: 1000 gallons

SIC: 4581

SCC: 40600126

Location/UTM(Km):
473E/3956N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Freeman Holding of CA, L.L.C.
18590 Readiness St.
Victorville, CA 92394

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

manufacturer/supplier and/or in a manner consistent with safety and good air pollution control practices for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 204]

2. Any modifications or changes to the piping of this system require prior approval from the District.

[District Rule 204]

3. The annual throughput of fuel shall not exceed 60,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.

[District Regulation XIII]

4. This tank shall be used to store aviation gasoline only. MSDS shall be maintained on-site and available and shall be provided to District personnel upon request.

[District Rule 204]

5. Vapor vent pipe is to be equipped with a Betts 6496ALB pressure relief valve or other equivalent valve set to within 10% of the maximum working pressure of the tank. The maximum pressure of this storage tank is 3.3 PSI.

[District Rule 463]

6. Hatch openings shall not be open more than three minutes for visual inspection and pumping shall be stopped at least three minutes prior to opening a hatch.

[District Rule 461]

7. The fill assembly is to be equipped with a spill bucket and dry break which prevent liquid spillage upon disconnect from exceeding 10 ml.

[District Rule 461]

8. This tank is to be inspected and maintained:

- a. The fill tube is to be equipped with a vapor tight cover with a properly seated and intact gasket.
- b. All dry breaks are to have vapor tight seals and be equipped with vapor tight covers or dust covers
- c. The fill tube assembly shall prevent vapor leakage from any portion of the vapor recovery system
- d. All tank vapor return pipes without dry breaks shall be equipped with a vapor tight cover with properly seated and intact gasket.

[District Rule 463]

9. The owner/operator shall maintain a log of the following:

- a. daily log of throughput
- b. inspections, repairs and maintenance performed on the tank
- c. cumulative annual throughput in gallons

The logs/other documentation shall be maintained on-site and available for two years and shall be made available to District personnel upon request.

[District Rule 463]

10. The owner/operator shall conduct TP-201.3B - Determination of Static Pressure of Vapor Recovery Systems of Dispensing Facilities with Above Ground Tanks within 60 days of construction completion and once every twelve months thereafter. TP201.3B has been approved by the Air Pollution Control Officer to determine compliance with fugitive vapor leak and fugitive liquid leak requirements pursuant to Rule 463(C)(3)(a). The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdaqmd.ca.gov
[District Rules 204 and 463]