



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

N012755

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JUNE 2024

OWNER OF OPERATOR (Co.#199)

SBCo Fleet Management Department
210 N Lena Road
San Bernardino, CA 92415-0842

EQUIPMENT LOCATION (Fac.#1116)

SBCo - Barstow Service Center
29802 Highway 58
Barstow, CA 92311

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

FUEL TANKS

| Tank No. | Material Stored | Volume (US Gallons) | Above/Underground |
|----------|-----------------|---------------------|-------------------|
| 1 | 87U | 10,000 | Above Ground |
| 2 | Diesel | 10,000 | Above Ground |

DISPENSING EQUIPMENT

| Fuel Type | Quantity |
|-----------|----------|
| 87U | 2 |
| Diesel | 2 |

VAPOR CONTROL EQUIPMENT

| Type | Equipment Name | Compliance |
|------|----------------|------------|
| PI | MB | VR-402 |
| PII | BAL | G-70-132-B |

Fee Schedule: 5 (a)

Rating: 10000 gallons

SIC: 9199

SCC: 40600603

Location/UTM(Km):
498E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

SBCo Fleet Management Department
210 N Lena Road
San Bernardino, CA 92415-0842

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

CONDITIONS:

1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the District's toll-free telephone number for complaints (1-800-635-4617).
[District Rule 461]

2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and available to the District upon request. Records of maintenance, tests, inspections, and test failures must be maintained and available to District personnel upon request. The record form must be similar to the Maintenance Record form indicated in Executive Order VR-402.
[District Rule 461; Executive Order VR-401]

3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.
[District Regulation XIII]

4. Pursuant to Executive Order VR-402, vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by the Executive Order.

5. The owner/operator shall perform the following tests within 60 days of construction completion, and at least once in every twelve month period in accordance with the following test procedures:

- a. Static Pressure Decay Test per CARB test method TP-201.3B (2-inch test);
- b. Liquid Removal Test per TP-201.6, TP-201.6C or Exhibit 5 (as applicable);
- c. Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves per TP-201.1E; and,
- d. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations; per CARB Method 21.

Summary of Test Data shall be documented on a Form similar to EO VR-402 Form 1.

If a FFS PV-Zero P/V vent valve is used, tests shall be conducted with the valve remaining in its installed position on the vent line(s) in accordance with PV-Zero section of the applicable ARB-Approved Installation, Operation and Maintenance Manual.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.
[District Rule 461]

6. Pursuant to Executive Order VR-402, maintenance and repair of system components, including removal and installation of such components in the course of any required tests, shall be performed by Morrison Bros Certified Technicians.

7. Pursuant to Executive Order VR-402, Maintenance Intervals for Morrison Bros, Tank Gauge Components, Dust Caps Emergency Vents, Phase I Product and Vapor Adapters, and Spill Container Drain Valve, shall be conducted by a Morrison Bros?trained technician annually.

8. The annual throughput of gasoline shall not exceed 600,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.
[District Regulation XIII; Health & Safety Code 44341 - 44342]

9. Pursuant to California Health and Safety Code sections 39600, 39601 and 41954, this aboveground tank shall be installed and maintained in accordance with Executive Order (EO) VR-402 for EVR Phase I, which includes Standing Loss requirements:
<https://www.arb.ca.gov/vapor/eos/eo-vr402/eo-vr402d/vr-402d.pdf>

Additionally, Phase II Vapor Recovery System shall be installed and maintained per G-70-132-B with the exception that hanging hardware shall be EVR Balance Phase II type hanging hardware (VST or other CARB Approved EVR Phase II Hardware).

10. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]?