



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B000908

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: FEBRUARY 2002

OWNER OF OPERATOR (Co.#460)

Sully-Miller Contracting, Co
135 State College Blvd Suite 400
Brea, CA 92821

EQUIPMENT LOCATION (Fac.#55)

Sully-Miller Contracting Co - Turner Rd
17540 Turner Road
Victorville, CA 92392

Description:

ELECTRIC GENERATOR consisting of:

One Caterpillar, 600kW, Diesel fired internal combustion engine Model No. D398 and Serial No. 66B2709, producing 865 bhp with cylinders at rpm while consuming a maximum of . This equipment powers a Model No. and Serial No. , rated at .

CONDITIONS:

1. This generator shall use diesel fuel whose sulfur content is = or < 0.05% on a weight/weight basis.
2. The owner/operator (o/o) shall maintain an operations log on-site for at least two (2) years and make available to District personnel on request. This log shall contain, as a minimum, the "hour meter" reading at the beginning and end of each day's operations, the total hours operated each day, and the gallons or pounds of fuel consumed. The o/o shall include the sulfur content of each delivery of diesel fuel. At the discretion of the District, the o/o shall collect a sample of diesel fuel and have it analyzed according to ASTM-2622-82 or other equivalent method for sulfur concentration and forward said results to the District upon receipt.
3. The o/o shall comply with all applicable District Rules including Regulation IV.
4. This generator shall be operated/maintained in strict accord with manufacturer's supplier's recommendations and/or sound engineering principles.

Fee Schedule: 1 (c)

Rating: 865 bhp

SIC: 2951

SCC: 9999999

Location/UTM(Km):
470E/3825N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Sully-Miller Contracting, Co
135 State College Blvd, Suite 400
Brea, CA 92821

By: **COPY**
Eldon Heaston
Air Pollution Control Officer