



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B001540

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: DECEMBER 2002

OWNER OF OPERATOR (Co.#248)

Sunray Energy, Inc
35100 E Santa Fe Road
Daggett, CA 92327

EQUIPMENT LOCATION (Fac.#899)

Sunray Energy - SEGS I
35100 E Santa Fe Road
Daggett, CA 92327

Description:

EMERGENCY OIL HEATER consisting of: Gas Fired, H-102, 2 x 10MM BTU/hr.

CONDITIONS:

1. The total consumption of natural gas to fire equipment associated with the generation of electric power by this system (SEGS I) in conjunction with SEGS II natural gas usage, shall not exceed 32,300 therms per day. The SEGS I equipment shall not exceed a nominal 3,750 therms of natural gas per day.
2. Operation of this equipment with an alternate fuel, without prior approval of the District is prohibited.
3. This equipment shall be operated and maintained in strict accord with manufacturer's and/or supplier's recommendations and/or sound engineering principles.

Fee Schedule: 2 (c)

Rating: 2000000 Btu

SIC: 4911

SCC: 99999999

Location/UTM(Km):
515E/3858N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Sunray Energy, Inc
PO Box 338
Daggett, CA 92327

By: **COPY**
Eldon Heaston
Air Pollution Control Officer