

MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

B003414

Inactive type Permit has no description information.

EXPIRES LAST DAY OF:OCTOBER 2014

OWNER OF OPERATOR (Co.#453)

Victor Valley Wastewater Reclamation Authority 20111 Shay Road Victorville, CA92394

EQUIPMENT LOCATION (Fac. #1124)

VVWRA - 20111 Shay 20111 Shay Road Victorville,CA92394

Description:

POTW - CHLORINATION SYSTEM consisting of: Chlorination system.

EQUIPMENT

Capacity	Equipment Description
3	Secondary Effluent Pump Station Injection Pump
5	Chlorine Contact Tank Jet Rector Pump
1.5	Chlorine Contact Tank Drain Pump
1.33	Chemical Feed Building Ferric Chloride Pump, 2 @ 0.67 hp
0.5	Chemical Feed Building Exhaust Fans, 2 @ 0.25 hp
20	Chemical Feed Building Unit Heaters, 3 @ 6.67 hp
100	Pond Pump Motor #3/#4
50	3W Pump #3 Motor

CONDITIONS:

1. This facility shall not treat more than 14.5 million gallons of waste water per day.

2.An operations log shall be maintained on-site for at least two (2) years and shall be made available to MDAQMD personnel on request. This log shall contain, as a minimum, the amount of waste water received and treated each day.

Fee Schedule:1 (b)

Rating:181.33bhp

SIC:4952

SCC:50100760

Location/UTM(Km):467E/3831N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victor Valley Wastewater Reclamation Authority P.O. Box 370 Adelanto,CA92301

By: COPY

Brad Poiriez

Air Pollution Control Officer

Page 1 of 2 Permit:B003414 Issue Date:10/31/2013

- 3. This equipment shall only be operated/maintained in strict accord with manufacturer's/supplier's recommendations; sound engineering principles; and/or federal, state, regional and local waste water discharge permits.
- 4.Emissions from this facility, including all stationary and portable emissions, may not exceed the following emission limits, based on a rolling 12 month summary:
- a. NOx 24.9 tons/year, verified by compliance tests and hours of operation,
- b. VOC as CH4 24.9 tons/year, verified by compliance tests and hours of operation,
- c. PM10 14.9 tons/year, verified by compliance tests and hours of operation,
- d. Single Federal Hazardous Air Pollutant (HAP) 9.9 ton/year, verified by emission calculations, and
- e. All HAPs 24.9 tons/year, verified by emission calculations.
- 5.A facility wide Comprehensive Emission Inventory (CEIR) for all emitted criteria and toxic air pollutant must submit to the District, in a format approved by the District, on a yearly basis, which is to be received by the District no later than April 30 of the following year.

Page 2 of 2 Permit:B003414 Issue Date:10/31/2013