



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B003976

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JANUARY 2007

OWNER OF OPERATOR (Co.#353)

Graham Equipment Co
17109 Eureka Street
Victorville, CA 92392

EQUIPMENT LOCATION (Fac.#1019)

Graham Equipment Co
17109 Eureka Street
Victorville, CA 92392

Description:

IC ENGINE, DIESEL GENERATOR consisting of: Powering the Aggregate Plant under District Permit B002286

One Caterpillar, Diesel fired internal combustion engine Model No. D333 and Serial No. 58B4102, producing 135 bhp with 8 cylinders at 1800 rpm while consuming a maximum of 4.0 gal/hr. This equipment powers a Generator Model No. and Serial No. , rated at 100 kW(e).

CONDITIONS:

1. This I.C. Engine shall only burn diesel fuel which shall not contain sulfur in excess of 0.05% by weight.
2. The owner/operator (o/o) shall require from the fuel supplier analytical results relating to the sulfur content of the fuel delivered and shall not accept delivery whenever the sulfur concentration exceeds 0.05% by weight.
3. The o/o shall maintain copies of these delivery results on-site and provide them to the District personnel on request.
4. An operations log shall be maintained on-site for at least two (2) years and be made available to District personnel on request. This log shall contain, as a minimum, the total hours operated each day, and if an "hour meter" is available, the reading at the beginning and end of each day; and the date and amount (gallons) of fuel delivery.
5. The o/o shall comply with all applicable Rules and Regulations of the District.

Fee Schedule: 1 (b)

Rating: 135 bhp

SIC: 1442

SCC: 20100102

Location/UTM(Km):
474E/3818N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Graham Equipment Co
17109 Eureka Street
Victorville, CA 92392

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

6. This I.C. Engine shall be operated/maintained in strict accord with manufacturer's/suppliers's recommendations and/or sound engineering principles.

7. A rebuild of this unit does not constitute a modification, so long as the model and rating are not changed. The o/o must notify the District in writing of any serial number change that results from a rebuild or identical replacement.