



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

B004270

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: SEPTEMBER 2026

OWNER OF OPERATOR (Co.#746)

Blythe, City of
440 S Main Street
Blythe, CA 92225

EQUIPMENT LOCATION (Fac.#1569)

Blythe, City of - Waste Water Treatment
15901 S Broadway
Blythe, CA 92225

Description:

WASTEWATER DISPOSAL PLANT consisting of:

EQUIPMENT

Capacity	Equipment Description
40	Dry Pit submersible vertical turbine pump, 40 hp (two 40 hp standby/backups)
6	Exhaust fans, 6 @ 1 hp each
0.3	Sump pump, 0.33 hp
0.3	Headworks Tower screw conveyor, 0.33 hp
1	Headworks Tower exhaust fan
140	Two Blower Turbine Building aeration basins centrifugal turbines, 100 hp and 40 hp (with two 100 hp standby/backup units)
30	RAS Pump Station vertical pumps, 2 @ 5 hp and 2 @ 10 hp
0.3	RAS Pump Station sump pump, 0.33 hp
10	Aerobic Digester centrifugal pumps, 2 @ 5 hp each
25	Aerobic Digester submersible aeration/mixing pump, 25 hp
1	Worm gear clarifiers, 2 @ 0.5 hp each.
1.33	Four scum pit pumps, 0.33 hp each

Fee Schedule: 1 (c)

Rating: 255.23 bhp

SIC: 4952

SCC: 50300781

Location/UTM(Km):
725E/3273N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Blythe, City of
235 N Broadway
Blythe, CA 92225

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

Capacity	Equipment Description
0	NOTE: The previously used equipment that was replaced by the above listed equipment is currently INACTIVE and an application for a Permit to Operate must be submitted to the District before it can be reactivated and put into service.

CONDITIONS:

1. A monthly record shall be maintained on-site for at least two (2) years and be made available to District personnel on request. This record shall contain, as a minimum, the amount of wastewater received and treated each day.
2. This equipment shall only be operated/maintained in strict accord with manufacturer's/supplier's recommendations; sound engineering principles; and/or federal, state, regional and local waste discharge permits.