



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B004271

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: OCTOBER 2005

OWNER OF OPERATOR (Co.#31)

Southern California Gas Co. - MD
9400 Oakdale Avenue
Chatsworth, CA 91313

EQUIPMENT LOCATION (Fac.#1437)

SCG - Blythe
13100 W 14th Avenue
Blythe, CA 92225

Description:

INTERNAL COMBUSTION ENGINE consisting of:

One Cummins, Diesel fired internal combustion engine Model No. 6BTA5.9-F2 and Serial No. 44736188, After Cooled, Turbo Charged, producing 130 bhp with 6 cylinders at 1800 rpm while consuming a maximum of. This equipment powers a Model No. and Serial No., rated at.

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be properly maintained and kept in good operating condition at all times.
3. The owner/operator (o/o) of this equipment shall comply with all applicable District Rules and Regulations.
4. The o/o shall not use diesel fuel whose sulfur concentration is 0.05% or less on w/w.
5. The o/o may use the supplier's sulfur analytical data, but at the discretion of the District, shall take a sample of the fuel and submit it for analysis by an independent laboratory. The results of said analyses, by ASTM method D 2622-82, shall be logged.

Fee Schedule: 1 (c)

Rating: 130 bhp

SIC: 4922

SCC: 99999999

Location/UTM(Km): 719E/3271N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Gas Co. - MD
PO Box 2300, SC 9314
Chatsworth, CA 91313-2300

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

6.A non-resettable elapsed operating time meter shall be installed and operated to determine the total operating time of this engine.

7.Operation records for this equipment must be maintained for a minimum of 2 years and shall be made available to District personnel upon request.