



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

B004308

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: SEPTEMBER 2025

OWNER OF OPERATOR (Co.#1732)

Helendale Community Services District
26540 Vista Road Suite B
Helendale, CA 92342

EQUIPMENT LOCATION (Fac.#1418)

Helendale Community Services District
28685 Helendale Road
Helendale, CA 92342

Description:

WASTEWATER-SLUDGE TREATMENT consisting of: an Aerobic Digester of approximately 210,000 gallons, whose drive motor is 1 hp; and 6 Sludge Drying Beds, each 100 ft by 25 ft. Facility Elevation is 2427 feet above sea level.

CONDITIONS:

1. Water drained from this sludge treatment system shall be returned to the primary and secondary treatment systems which are described on District permit B004306.
2. This facility shall not treat more than 1.2 millions gallons of waste water per day.
3. The owner/operator, o/o, shall log the daily volume of wastewater received and treated. The log shall be maintained current, on-site for a minimum of 2 years and provided to District personnel on request.
4. The o/o shall operate and maintain this equipment in strict accord with those recommendations of the manufacturer and/or federal, State, regional and local waste water discharge permits.
5. The o/o shall notify the District when the flow rate becomes sufficiently high to require the use of the normally spared equipment in the description above, which would indicate full operation of the facility. When this occurs, the District will modify this permit to reflect the capacity changes. NOTE: The flow rate at the writing of this permit was sufficiently low, (e.g., 0.4-0.6 million gallons per day) to allow

Fee Schedule: 1 (a) Rating: 1bhp SIC: 4952 SCC: 50100795 Location/UTM(Km): 470E/3848N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Helendale Community Services District
P.O. Box 359
Helendale, CA 92342-0359

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

alternate operation of equipment at any one time. Some systems are rotated into operation on a monthly basis.

6.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]