MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B004783

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2000

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#4516)

NTC Fort Iwin Wastewater Treatment Plant
Bldg. 602, 5th Street
Fort Irwin, CA 92310

Description:
WASTEWATER TREATMENT PLANT-DISINFECTION consisting of: Building 700. Chlorine delivery (and its attendant 0.5 hp each mixer and water pump) and the chlorine contact chamber (42' x 36' x 10' deep). Daily use of Cl2 is expected to be approximately 200 lb.

CONDITIONS:

1. The owner/operator (o/o) shall operate and maintain all equipment described in this permit in strict accord with all the submittals attendant with the application and/or sound engineering principles.

UNOFFICIAL

Fee Schedule: 1 (a)	Rating: 1 bhp	SIC: 9511	SCC: 99999999	Location/UTM(Km): 529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA 92310

By: **COPY**
Brad Poiriez
Executive Director