



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B004796

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: OCTOBER 1999

OWNER OF OPERATOR (Co.#460)

Sully-Miller Contracting, Co
135 State College Blvd Suite 400
Brea, CA 92821

EQUIPMENT LOCATION (Fac.#1693)

Sully-Miller Contracting Co - Various
District Wide
MDAQMD, CA 92392

Description:

ELECTRICITY GENERATOR consisting of: Diesel fired Caterpillar Model No 3508 rated at 920 BHP. This engine is turbo-charged, aftercolled and has the ignition retarded 4 degrees. This engine burns approximately 23 gal/h. The necessary electrical, piping and fuel tank and connections are included.

CONDITIONS:

1. This equipment shall be installed, maintained and operated in strict accord with those recommendations of the manufacturer and/or sound engineering which produce the minimum emissions of contaminants.
2. This equipment shall comply with all applicable conditions of District Rule 1160.
3. Commencing in calendar 1999, and in every odd year thereafter, the o/o shall conduct compliance testing in strict accord with the previously accepted protocol ETE 011597 PRO. This protocol has followed the procedures delineated in the District's Compliance Test Procedural Manual. Testing shall be completed within 180 calendar days from the date of expiry of the permit. The final report dispatched to the District no later than 60 calendar days from the date of expiry of this permit.
4. This equipment is limited to 3450 hours of operation per calendar year. The o/o shall log the starting and stopping times of this unit on each day it is used. The o/o shall also log the fuel used in this unit from purchases on a quarterly basis. This log shall be maintained current, on-site for a minimum of 2 years and provided to District personnel on request.
5. The sulfur content of the fuel used in this equipment shall be equal to or less than 0.05% on a mass per mass basis. The o/o shall use no other fuel but diesel without prior written approval of the District APCO.

Fee Schedule: 1 (c)

Rating: 920 bhp

SIC: 2951

SCC: 99999999

Location/UTM(Km):
473E/3956N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Sully-Miller Contracting, Co
135 State College Blvd, Suite 400
Brea, CA 92821

By: **COPY**
Eldon Heaston
Air Pollution Control Officer