



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**PERMIT TO OPERATE**

B005054

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: FEBRUARY 2027**

**OWNER OF OPERATOR (Co. #97)**

HDMC Holdings, LLC  
6601 White Feather Road  
Joshua Tree, CA 92252

**EQUIPMENT LOCATION (Fac. #427)**

Hi-Desert Medical Center  
6601 White Feather Road  
Joshua Tree, CA 92252

**Description:**

BOILER (#1) consisting of: Model XFC-2500-LN with low NOx burners Model LNICR2-GO-20B, natural gas and No. 2 fuel oil backup; rated @ 2.5 million Btu/hr for space heating. An associated 800,000 Btu/hr dual-fueled boiler furnishes low pressure steam to air conditioning humidifiers, #1 Serial # 52170. Equipment Elevation is 2653 feet above sea level.

**CONDITIONS:**

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit was issued unless otherwise noted below.
2. This unit shall not operate simultaneously with the equipment described in District permit M005055 except during start-up of one unit and ramp-down/shut-down of the other.
3. This unit shall normally be fired on pipeline regulated natural gas.
4. The owner/operator (o/o) shall notify the District APCO when fuel oil is fired in this equipment.
5. The o/o shall use only diesel fuel whose sulfur concentration is equal or less than 0.05% on a weight per weight basis.

Fee Schedule: 2 (c)

Rating: 2500000 Btu

SIC: 8062

SCC: 10300603

Location/UTM(Km):  
567E/3777N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

HDMC Holdings, LLC  
PO Box 2186  
Chesterton, IN 46304

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

6. The o/o shall maintain a log which, as a minimum, contains:

a. Date and length of time the engine is operated.

B. Type and quantity of fuel burned.

C. Sulfur content of the fuel. The o/o may use the supplier's furnished certification of sulfur content if the certifications are maintained on file as part of the log.

7. The o/o shall maintain the log current, on-site for a minimum of two years and provide to District personnel upon request.

8. The o/o shall operate all equipment described in this permit in strict accord with the recommendations of the manufacturer or supplier and/or sound engineering principles.

9. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]