



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B007579

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: OCTOBER 2000

OWNER OF OPERATOR (Co.#90)

Omya (California) Inc
7299 Crystal Creek Road
Lucerne Valley, CA 92356

EQUIPMENT LOCATION (Fac.#461)

Omya - Main Plant
7299 Crystal Creek Road
Lucerne Valley, CA 92356

Description:

FLASH HEATER consisting of: 5 million Btu/h, which is started up on propane. This unit generally uses about 36 gal/h of No. 2 fuel oil and about 0.6 gal/h of propane to start up. The exhaust of this unit is discharged to the Raymond Mill and then to the cyclone/scrubber.

CONDITIONS:

1. This equipment shall not use diesel fuel whose sulfur concentration exceeds 0.05 % on a weight per weight basis.
2. The owner/operator, o/o, shall maintain a log of the annual fuel consumption for this unit. The o/o shall maintain the unit on site and provide it to District personnel on request.

Fee Schedule: 2 (d)

Rating: 5000000 Btu

SIC: 1422

SCC: N/A

Location/UTM(Km):
505E/3805N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Omya (California) Inc
7225 Crystal Creek Rd
Lucerne Valley, CA 92356

By: **COPY**
Brad Poiriez
Executive Director