



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B007942

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: OCTOBER 2008

OWNER OF OPERATOR (Co.#1654)

New Cingular Wireless PCS, LLC
311 S. Akard Street, 12th Floor
Dallas, TX 75202

EQUIPMENT LOCATION (Fac.#2346)

New Cingular Wireless - Pole Line Dr
16433 Pole Line Drive
Havasu Lake, CA 92363

Description:

DIESEL IC ENGINE, PRIMARY GENERATOR consisting of:

One Onan/Cummins, Diesel fired internal combustion engine Model No. 6BT59-G6 and Serial No. 45943659, Direct Injected, Turbo Charged, producing 170 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 6.0 gal/hr. This equipment powers a Onan Generator Model No. DGDB3388538 and Serial No. B000062590, rated at 100kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
NOx	6.9	gal/hr

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit was issued unless otherwise noted below.
2. The owner/operator (o/o) shall use only ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% on a weight per weight basis per CARB Diesel or equivalent requirements.

Fee Schedule: 1 (b)

Rating: 170 bhp

SIC: 4813

SCC: 20100102

Location/UTM(Km):
760E/3800N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

New Cingular Wireless PCS, LLC
ATTN: EH&S

Dallas, TX 75202

By: **COPY**
Brad Poiriez
Executive Director

3. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

4. The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, with records kept on-site for two (2) years, and be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- c. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).