



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**PERMIT TO OPERATE**

B008639

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: JULY 2026**

**OWNER OF OPERATOR (Co.#2)**

CALNEV Pipe Line, LLC  
1001 Louisiana Street  
Houston, TX 77002-5089

**EQUIPMENT LOCATION (Fac.#353)**

CALNEV - Barstow Terminal  
34277 Daggett-Yermo Road  
Daggett, CA 92327

**Description:**

ETHANOL TANKER TRUCK UNLOADING SYSTEM consisting of: Two 4-inch unloading hoses, Two High Capacity Submerged Turbine Pumps, Air Eliminator, Strainer, High Performance Low Fugitive Emission Valves, Flanges, and associated piping.

**CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rules 204 and 1303]
2. This unloading system shall only transfer denatured ethanol to the organic liquid storage tank operating under valid District Permit T000096 (Tank 330). [District Rules 462 and 1303]
3. The owner/operator shall maintain a log of all inspections, repairs, and maintenance on this equipment current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall contain, as a minimum, the following requirements from District Rule 1102:
  - a. Inspection Requirements in accordance with District Rule 1102(D);
  - b. Repair Requirements in accordance with District Rule 1102(E); and

Fee Schedule: 1 (a)

Rating: 10 bhp

SIC: 5171

SCC: 40400151

Location/UTM(Km):  
510E/3859N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CALNEV Pipe Line, LLC  
1001 Louisiana Street  
  
Houston, TX 77002-5089

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

c. Recordkeeping and Reporting Requirements in accordance with District Rule 1102(G)(1).  
[40 CFR 70.6(a)(3)(ii)(b), District Rules 462 and 1102]

4. Test methods for compliance verification shall be in accordance with District Rule 1102(H).  
[District Rule 1102]

5. The vapor balance line shall be connected to the tanker truck during all offloading operations.  
[District Rules 1303 and 1320]