MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

RENEWAL

B009055

Renewal type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2026

OWNER OF OPERATOR (Co.#86)

MAGTFTC MCAGCC
Box 788110, Bldg 1418
Twentynine Palms, CA 92278-8110

EQUIPMENT LOCATION (Fac.#3247)

USMC AGCC - USMC Facilities
Box 788110, Bldg. 1451
Twentynine Palms, CA 92278

Description:
POWER TEST DYNAMOMETER consisting of: BUILDING 2000, for testing engines removed from mobile/stationary equipment, and equipped with a 40' tall x 23" diameter exhaust stack.

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with data and specifications submitted with the application under which this permit was issued unless otherwise stated below.

2. The owner/operator (o/o) shall operate this equipment in strict accord with the manufacturer's specifications and/or sound engineering principles.

3. The o/o shall maintain a log of operations on this equipment which contains at a minimum the following:
a. Fuel consumed by the operating engines
b. Date, time, and length of times of each engine's operation, and
c. Brake hp of the engine developed at maximum during testing

4. The o/o shall keep the log on-site for a minimum of five (5) years and provide it to the District personnel on request.

Fee Schedule: 1 (c)	Rating: 300 bhp	SIC: 9711	SCC: 99999999	Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC
Box 788110, Building 1418

Twentynine Palms, CA 92278-8110

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL

5. The engines tested are limited to using diesel fuel whose sulfur content does not exceed 0.05% on a weight per weight basis (or JP-8 as appropriate).

6. This facility shall comply with District Rule 222-Limitations on Potential to Emit. Compliance with this rule will be demonstrated to the District on an annual basis through the submission of an approved Comprehensive Emission Inventory Report (CEIR). A copy of the most recent CEIR shall be maintained on-site and presented to District personnel upon request.