



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B009140

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MAY 2010

OWNER OF OPERATOR (Co.#46)

Victorville, City of
14343 Civic Drive
Victorville, CA 92392-2399

EQUIPMENT LOCATION (Fac.#2723)

Victorville - Foxborough
12961 Enterprise Way
Victorville, CA 92395

Description:

DUCT BURNER (DB-01) consisting of: A Coen natural gas-fired 55.9 MMBtu/hr duct burner adding supplemental heat to CTG-01 (B009134). The exhaust from this unit is treated by SCR and oxidation catalyst.

EQUIPMENT

Capacity	Equipment Description
33.6	Duct Burner, rated 33.6 MMBtu/hr of heat input under supplemental firing
22.3	Additional 22.3 MMBtu/hr of heat input under fresh air firing (maximum rating 55.9 MMBtu/hr)

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be exclusively fueled with natural gas or propane and shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.

Fee Schedule: 2 (e)

Rating: 55900000 Btu

SIC: 9199

SCC: 20100201

Location/UTM(Km):
473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victorville, City of
Public Works - Fleet Division

Victorville, CA 92392-2399

By: **COPY**
Brad Poiriez
Executive Director

3. This duct burner shall not be operated unless the selective catalytic NOx reduction system with valid District permit C009137 is in operation.

4. Annual fuel use by this equipment (in MMcf and/or gallons) shall be recorded and maintained on site for a minimum of five (5) years and shall be provided to District personnel on request.