



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B009995

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: AUGUST 2019**

**OWNER OF OPERATOR (Co.#967)**

SBCo Facilities Management Department  
200 South Lena Road  
San Bernardino, CA 92415-0055

**EQUIPMENT LOCATION (Fac.#2999)**

SBCo - Barstow Law & Justice Center  
235 E Mountain View  
Barstow, CA 92311

**Description:**

BOILER consisting of: A Lochinvar natural-gas fired Copper-Fin II Model CHN 20071-M7, Serial No. F07H00198234 water boiler, equipped with 23 Lochinvar Model BNR 3422 low NOx burners and rated 2.070 MMBtu/hr based on fuel input (2070 cubic feet per hour), providing water and space heating at the Barstow Law and Justice Center. This unit is guaranteed to emit less than 30 ppmvd NOx at three percent oxygen.

**EQUIPMENT**

Capacity	Equipment Description
21.735	Lochinvar Steam Boiler (rated 2.174 MMBtu/hr)

**CONDITIONS:**

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants.
3. The operator shall maintain a log for this equipment, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:

Fee Schedule: 2 (c)

Rating: 2173500 Btu

SIC: 9223

SCC: 10300603

Location/UTM(Km):  
498E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

SBCo Facilities Management Department  
200 South Lena Road  
San Bernardino, CA 92415-0055

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

- a. Cumulative annual fuel use in cubic feet or operation in hours; and,
- b. Annual tune-up verification.

4. Prior to the expiration date each year (beginning in 2008), the o/o shall have this equipment tuned, as specified by Rule 1157.