



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

**B010239**

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 2009**

### **OWNER OF OPERATOR (Co.#84)**

NTC - Public Works  
Bldg 602, 5th Street  
Fort Irwin, CA 92310

### **EQUIPMENT LOCATION (Fac.#589)**

NTC Training Mission  
Bldg. 602, 5th street  
Fort Irwin, CA 923105085

#### **Description:**

DIESEL IC ENGINE, PORTABLE GENERATOR consisting of: FOB Seattle, Yr of Mfg 2008; TIER 2, USEPA Family Name 8CEXL0275AAG, CARB Executive Order # U-R-002-0042

One Cummins, Diesel fired internal combustion engine Model No. QSB5-G3NR3 and Serial No. 21834181, Turbo Charged, producing 115 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 5.0 gal/hr. This equipment powers a Cummins Generator Model No. DSFAD and Serial No. CO80168823, rated at 80 kw.

#### **EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	0.56	gm/bhp-hr
NOx	2.2	gm/bhp-hr
PM10	0.06	gm/bhp-hr
SOx	0.15	gm/bhp-hr
VOC	0.05	gm/bhp-hr

#### **CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

2. This portable equipment shall not be operated and/or located within 1,000 feet of a public or private school (kindergarten through 12th

Fee Schedule: 1 (b)      Rating: 115 bhp      SIC: 9711      SCC: 20100102      Location/UTM(Km): 529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works  
Attn: Air Resources Manager  
  
Fort Irwin, CA 92310

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

grade) of more than 12 students for more than 30 consecutive days without completing the notification required by Health and Safety Code \S\S 42301.6.

3.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

4.This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. [Title 17 CCR 93116.2(bb)]

5.This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15 ppm) a weight per weight basis per CARB Diesel or equivalent requirements.

6.The owner/operator (o/o) shall maintain a operations log for this unit current and on-site, either at the engine location or at a on-site location, for a minimum of two (2) years, and for another year where it can be made available to the District staff within 5 working days from the District's request, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

7.This unit shall not be operated in the Mojave Desert AQMD for more than 4,032 hours in any calendar year.

8.This unit can only be used as "Tactical Support Equipment" as defined in Title 17 CCR 93116.2(a)(36) for Tactical Support Training. Tactical Support Equipment (TSE) means equipment using a portable engine, including turbines, that meets military specifications, owned by the U.S. Department of Defense and/or the U.S. military services or its allies, and used in combat, combat support, combat service support, tactical or relief operations, or training for such operations. Examples include, but are not limited to, engines associated with portable generators, aircraft start carts, heaters and lighting carts.