

## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

### **INACTIVE**

B010318

Inactive type Permit has no description information.

#### **EXPIRES LAST DAY OF: APRIL 2009**

# OWNER OF OPERATOR (Co.#46)

Victorville, City of 14343 Civic Drive

# EQUIPMENT LOCATION (Fac. #2948)

Victorville 2 Hybrid Power Project Perimeter Road Victorville,CA92392

# **Description:**

COOLING TOWER consisting of:Water circulation, treatment and handling equipment, and air circulation equipment serving the combustion turbine power blocks under B010309 and B010314. Manufacturer, model and serial numbers will be specified when known.

### **CONDITIONS:**

Victorville, CA92392-2399

- 1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
- 2. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.
- 3. The drift rate shall not exceed 0.0005 percent with a maximum circulation rate of 130,000 gallons per minute. The maximum hourly PM10 emission rate shall not exceed 1.63 pounds per hour, as calculated per the written District-approved protocol.
- 4. The operator shall perform weekly tests of the blow-down water quality total dissolved solids (TDS). The operator shall maintain a log which contains the date and result of each blow-down water quality test in TDS ppm, and the resulting mass emission rate. This log shall be maintained on site for a minimum of five (5) years and shall be provided to District personnel on request.
- 5. The operator shall conduct all required cooling tower water quality tests in accordance with a District-approved test and emissions calculation protocol. Thirty (30) days prior to the first such test the operator shall provide a written test and emissions calculation protocol for District review and approval.

Fee Schedule:7 (h)

Rating:1device

SIC:4911

SCC:99999999

Location/UTM(Km):467E/3828N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victorville, City of Public Works - Fleet Division

Victorville, CA92392-2399

By: COPY
Brad Poiriez
Air Pollution Control Officer

6.A maintenance procedure shall be established that states drift eliminators. This procedure is to be kept on-site and available.	how often and what procedures wailable to District personnel on req	ill be used to ensure the integrity ouest.	of the

Page 2 of 2 Permit:B010318 Issue Date:08/01/2008