



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B010617

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2015

OWNER OF OPERATOR (Co.#2830)

Trogon Development, LLC
37000 Santa Fe Street
Daggett, CA 92327

EQUIPMENT LOCATION (Fac.#1880)

Coolwater Generating Station
37000 Santa Fe Street
Daggett, CA 92327

Description:

COOLING TOWER (UNIT 1) consisting of: A Foster Wheeler Model 59-C-6-B-10-H cooling tower circulating 41,600 gallons per minute through ten cells and equipped with a 99.98% drift eliminator. This device was constructed prior to 1978 and serves Unit 1 (B001077).

CONDITIONS:

1. The owner/operator (o/o) shall maintain this equipment in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants.
2. The maximum hourly PM10 emission rate shall not exceed 16.65 pounds per hour, by not exceeding a total dissolved solids concentration of 4000 milligrams per liter at a design circulation rate of 41,600 gallons per minute and design drift loss rate of 0.02%. The o/o shall verify compliance with this condition by maintaining the circulation water total dissolved solids concentration below 4000 milligrams per liter and logging those values and the date of the test at least once during each month of operation, retaining this log on-site for at least five (5) years and providing this log to District, State or Federal personnel upon request.

Fee Schedule: 7 (i)

Rating: 1 device

SIC: 4911

SCC: 99999999

Location/UTM(Km): 513E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Trogon Development, LLC
P.O. Box 1605
Canovanas, PR 00729

By: **COPY**
Brad Poiriez
Air Pollution Control Officer