



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B010627

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: MARCH 2012**

**OWNER OF OPERATOR (Co.#1795)**

Las Vegas Paving  
4420 South Decatur Blvd.  
Las Vegas, NV 89103

**EQUIPMENT LOCATION (Fac.#3044)**

Las Vegas Paving - Yates Well Rd  
Intersection Yates Well & I-15  
Mountain Pass, CA 92364

**Description:**

DIESEL IC ENGINE, PORTABLE GENERATOR consisting of: YOM is 2006; Tier 3, CARB E.O # U-R-001-0287, EPA Family Name 6CPXL08.8ESK

One Caterpillar, Diesel fired internal combustion engine Model No. C9 and Serial No. S9L00886, Direct Injected, Turbo Charged, After Cooled, producing 480 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 23.0 gal/hr. This equipment powers a TBD Generator Model No. TBD and Serial No. TBD, rated at .

**EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	2.31	gm/bhp-hr
NOx	2.35	gm/bhp-hr
PM10	0.11	gm/bhp-hr
SOx	0.17	gm/bhp-hr
VOC	0.41	gm/bhp-hr

**CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

Fee Schedule: 1 (c)

Rating: 480 bhp

SIC: 2951

SCC: 20200102

Location/UTM(Km):  
634E/3927N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Las Vegas Paving  
4420 South Decatur Blvd.  
Las Vegas, NV 89103

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

2. This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. (This system must be moved within this facility or moved to another facility annually.) [Title 17 CCR 93116.2(bb)]
3. This diesel ICE and its associated equipment (generator) shall not operate at this location after July 1, 2011.
4. This equipment shall not operate more than sixteen (16) hours per day. Additionally, this equipment shall not operate more than 1600 hours per calendar year.
5. The owner/operator shall notify the District in writing 10 days prior to each annual initial start-up of this equipment.
6. This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) on a weight per weight basis per CARB Diesel or equivalent requirements; or alternative diesel fuel or CARB diesel fuel utilizing fuel additives that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines. [Title 17 CCR 93116.3(a)]
7. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.
8. The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:
  - a. Date of each use and duration of each use (in hours);
  - b. Reason for use (Regular use, testing & maintenance, emergency, required emission testing);
  - c. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
  - d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log). [Title 17 CCR 93116.4(c)]
9. The o/o of this unit must submit a Status Report for the entire fleet\* by March 1, 2011. This Status Report should include, but not limited to, the following, for details see Title 17 CCR 93116.4(e)(1):
  - a. The fleet's weighted average PM emission rate for the 2010 calendar year,
  - b. Inventory of portable engines in the fleet,
  - c. Identify, if applicable, each portable diesel-fueled engine that the owner commits to replacing with a Tier 4 engine,
  - d. Listing of portable diesel-fueled engines, if applicable, used exclusively in emergency applications,
  - e. Listing of portable diesel-fueled engines, if applicable, satisfying the low-use engine requirements,
  - f. Listing of portable alternative-fueled engines, if applicable, added to the fleet prior to January 1, 2009, pursuant to section 93116.3(d)(2)(B)2, and
  - g. Listing of portable diesel-fueled engine(s) equipped with Selective Catalytic Reduction (SCR) system(s),

\* Fleet is defined in Title 17 CCR Section 93116.2(p) as one or more portable unit(s).

10. The fleet\* under control of this o/o is subject to and shall comply with the weighted Diesel Particulate Matter (DPM) emission fleet averages\*\* expressed as grams per brake horsepower-hour (g/bhp-hr) of Title 17 CCR Section 93116.3(c) & (d) by the following dates:

Compliance Date Weighted DPM (g/bhp-hr)

January 1, 2013 0.30

January 1, 2017 0.18

January 1, 2020 0.04

\* Fleet is defined in Title 17 CCR Section 93116.2(p) as one or more portable unit(s).

\*\* The method used to calculate the Fleet Average is found in Title 17 CCR 93116.3(d).

11. The o/o of this unit must submit a Statement of Compliance signed by the Responsible Official that the fleet standards are being achieved and a summary that identifies each portable engine in the fleet and the associated emission rate (g/bhp-hr) and other required information, see Title 17 CCR 93116.4(e)(2), (3), (4), (5), (6) and (7) for the following compliance statement submittal dates:

Weighted DPM Emission Fleet Average Date Submit by

January 1, 2013 March 1, 2013

January 1, 2017 March 1, 2017

January 1, 2020 March 1, 2020

12. This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Portable Compression Ignition Engines (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the requirements of the ATCM shall govern.