



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B010652

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: SEPTEMBER 2010**

**OWNER OF OPERATOR (Co.#46)**

Victorville, City of  
14343 Civic Drive  
Victorville, CA 92392-2399

**EQUIPMENT LOCATION (Fac.#3132)**

City of Victorville - Nutro Way  
13243 Nutro Way  
Victorville, CA 92395

**Description:**

BOILER, NATURAL GAS consisting of: One Cleaver Brooks Boiler Model CD200-350-200-LE, Serial Number OLO95182, National Board Number 8027, manufactured in 1996, natural gas-fired steam boiler, rated at 15.435 MMBtu/hr max heat input (natural gas), equipped with a Cleaver Brooks L-E burner and oxygen trim (max 30 ppmvd NOx at 3% oxygen), providing hot water and steam.

**EQUIPMENT**

Capacity	Equipment Description
15.435	Cleaver-Brooks Boiler rated 15.435 MMBtu/hr

**CONDITIONS:**

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants.
3. The operator shall maintain a log for this equipment, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:
  - a. Cumulative annual fuel use in cubic feet;

Fee Schedule: 2 (e)

Rating: 15435000 Btu

SIC: 4961

SCC: 10200602

Location/UTM(Km):  
474E/3817N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victorville, City of  
Public Works - Fleet Division  
  
Victorville, CA 92392-2399

By: **COPY**  
Eldon Heaston  
Air Pollution Control Officer

- b. Annual compliance test or tune-up verification; and,
- c. Any repairs or modifications to the burner.

4. Not later than 180 days after initial startup, the operator shall perform an initial compliance test on this equipment in accordance with the District Compliance Test Procedural Manual. This test shall demonstrate that this equipment does not exceed 30 ppmvd NO<sub>x</sub> as NO<sub>2</sub> at 3% oxygen at its maximum natural gas firing rate.

5. This equipment shall be equipped with a fuel meter.

6. Prior to the expiration date each year (beginning in 2010), the o/o shall either perform a NO<sub>x</sub> and CO compliance test, or have this equipment tuned, as specified by Rule 1157. A tune-up may be performed in lieu of a compliance test during those permit years when the annual heat input to this unit does not exceed 50,000 MMBtu per year.