



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**PERMIT TO OPERATE**

B010828

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: NOVEMBER 2026**

**OWNER OF OPERATOR (Co.#88)**

NAWS  
429 E Bowen Road - Stop 4014  
China Lake, CA 93555-6108

**EQUIPMENT LOCATION (Fac.#567)**

NAWCWD Test Stands  
429 E Bowen Road - Stop 4014  
China Lake, CA 935556108

**Description:**

DIESEL IC ENGINE, GENERATOR (SUPERIOR VALLEY) consisting of: A certified Tier III diesel engine manufactured in 2009, EPA Family 9JDXL09.0114, equipped with a Level 3 verified (ARB Executive Order DE-08-009-01) diesel particulate filter manufactured by Johnson Matthey. Engine exhaust flow is 1930 ACFM at 882 degrees Fahrenheit.

One John Deere, Diesel fired internal combustion engine Model No. 6090HF and Serial No. RG6090L076421, Direct Injected, Turbo Charged, After Cooled, Smoke Puff Limiter, Electronic Control Module, , producing 315 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 16.0 gal/hr. This equipment powers a Kohler Generator Model No. 250RE0ZJD and Serial No. 2283794, rated at TBD.

**EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	2.61	gm/bhp-hr
NOx	2.84	gm/bhp-hr
PM10	0.02	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.15	gm/bhp-hr

**CONDITIONS:**

Fee Schedule: 1 (c)

Rating: 315 bhp

SIC: 9711

SCC: 20100102

Location/UTM(Km):  
450E/3946N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NAWS  
Environmental Management Division  
China Lake, CA 93555-6108

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

1. This certified stationary compression-ignited internal combustion engine and its associated emission control systems shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.  
[District Rule 204; 40 CFR 60.4211(a) and (c)]
  
2. A non-resettable hour meter with a minimum display capability of 9,999 hours shall be installed and maintained on this unit to indicate elapsed engine operating time.  
[District Rule 204; 17 CCR 93115.10(d)]
  
3. The owner/operator must purchase diesel fuel for this engine that meets the requirements of 40 CFR 80.510(b) for nonroad diesel fuel, which are as follows:
  - (a) A sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,
  - (b) A cetane index or aromatic content, as follows:
    - (1) A minimum cetane index of 40; or,
    - (2) A maximum aromatic content of 35 volume percent.[40 CFR 60.4207(b)]  
Note: Use of CARB certified ULSD fuel satisfies the above requirements.
  
4. The owner/operator shall maintain an operations log for this engine current and on-site (or at a central location) for a minimum of five (5) years, and shall include, at a minimum, the following information:
  - (a) Monthly and consecutive 12 month rolling period operation in terms of fuel consumption (in total hours);
  - (b) Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content. Such certification may be stored separately from the remainder of the log);
  - (c) Maintenance and repair actions performed on the engine;
  - (d) Maintenance and repair actions performed on both the Diesel Particulate Filter and its associated backpressure monitor; and
  - (e) Records of all performance tests and evaluations.[17 CCR 93115.10; 40 CFR 70.6(a)(3)(ii)(b)]
  
5. The Diesel Particulate Filter must be equipped with a backpressure monitor that notifies the owner or operator when the high backpressure limit of the engine is approached.  
STATE AND DISTRICT ENFORCEABLE ONLY  
[17 CCR 93115.10(d)]
  
6. This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (NSPS).  
[District Rule 1302]
  
7. This engine shall not be operated unless all of the following emission control systems are properly functioning:
  - (a) Diesel Particulate Filter;
  - (b) Electronic Control Module; and
  - (c) Backpressure MonitorFurthermore, no changes shall be made to any of the above systems unless done so by a factory certified technician.  
[District Rule 1302; 40 CFR 60.4211]
  
8. This engine shall not be operated for more than 7,122 hours in any consecutive twelve month period. This reduction in operating hours allows an increase in operating hours for the diesel-fueled IC Engine described in District Permit B012374.  
[District Rules 204 and 1303]
  
9. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.  
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]