



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B010898

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2022

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#589)

NTC Training Mission
Bldg. 602, 5th street
Fort Irwin, CA 923105085

Description:

DIESEL IC ENGINE, PORTABLE GENERATOR (STORED AT BLDG 802) consisting of: A certified Tier 2 Compression-Ignition (Diesel) Portable Prime Use Engine, EPA Family 6SZXL04.3GTG with no exhaust after-treatment system installed:

One ISUZU, Diesel fired internal combustion engine Model No. FF-4BG1T and Serial No. 925683, After Cooled, Compression-Ignited, Direct Injected, Turbo Charged, producing 87 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 4.4 gal/hr. This equipment powers a MQ POWER CORP Generator Model No. DCA-70SSI and Serial No. 3784161, rated at 56 kW(e).

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	1.12	gm/bhp-hr
NOx+NMHC	5.00	gm/bhp-hr
PM10	0.164	gm/bhp-hr
PM2.5	0.164	gm/bhp-hr
SOx	0.005	gm/bhp-hr

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

Fee Schedule: 1 (b)

Rating: 87 bhp

SIC: 9711

SCC: 20100102

Location/UTM(Km):
529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA 92310

By: **COPY**
Brad Poiriez
Executive Director

2. This diesel engine and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. (This system must be moved for a valid operational reason within this facility or moved to another facility annually.)

[Title 17 CCR 93116.2(bb)]

3. This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) per CARB Diesel or equivalent requirements; or alternative diesel fuel or CARB diesel fuel utilizing fuel additives that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines.

[Title 17 CCR 93116.3(a)]

4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

[Title 17 CCR 93116.4(c)(2)(A)]

5. This portable engine shall not be operated within 1,000 feet of a public or private school (kindergarten through 12th grade) of more than 12 students without completing the notification required by Health and Safety Code 42301.6.

[CA Health and Safety Code, Section 42301]

6. The o/o shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Location of use;
- c. Reason for use (Regular use, testing & maintenance, required emission testing);
- d. Calendar year operation in terms of fuel consumption (in gallons) or total hours; and,
- e. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

[Title 17 CCR 93116.4(c)]

7. The o/o of this unit must submit a Statement of Compliance signed by the Responsible Official that the fleet standards are being achieved and a summary that identifies each portable engine in the fleet and the associated emission rate (g/bhp-hr) and other required information, see Title 17 CCR 93116.4(e)(2), (3), (4), (5), (6) and (7) for the following compliance statement submittal dates:

// Fleet DPM Emission Average Date // Date Report is Due

January 1, 2017 // March 1, 2017

January 1, 2020 // March 1, 2020

===

*Fleet is defined in Title 17 CCR Section 93116.2(p) as one or more portable unit(s).

[17 CCR 93116.4]

8. This facility shall emit less than the following on an annual (any twelve consecutive month period) basis to remain under the USEPA's Synthetic Minor, 80% (SM-80) limits;

Oxides of Nitrogen (NOx) - 20 tons,

Volatile Organic Compound (VOC) - 20 tons,

Particulate Matter less than 10 microns (PM10) - 12.5 tons, and

Hazardous Air Pollutants (HAP) - 8 tons per year for any single HAP and 20 tons per year for any combination of HAPs.

Compliance shall be demonstrated annually to the District through the submission of a District approved Comprehensive Emission Inventory Report (CEIR) or other District approved equivalent method. The report shall be submitted to the District no later than April 30 of each year.

[District Rules 1302 and 1520]

9. This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Portable Compression Ignition Engines (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern.
[Title 17 CCR 93116; District Rule 1302]

10. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]