

MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

В010912

Inactive type Permit has no description information.

EXPIRES LAST DAY OF:SEPTEMBER 2022

OWNER OF OPERATOR (Co.#1584)

ComAV Technical Services LLC 18438 Readiness Street Victorville,CA92394

EQUIPMENT LOCATION (Fac.#2675)

ComAV Technical Services 18438 Readiness Street Victorville, CA92394

Description:

DIESEL IC ENGINE, PORTABLE START CART consisting of:A certified Tier 2 diesel engine, EPA Family 4DDXL14.0VLD, manufactured in 2004 with no after-exhaust emission control devices installed. Exhaust flow is approximately 3900 ACFM at 888 degrees Fahrenheit.

OneDetroit Diesel, Diesel fired internal combustion engine Model No.6063HK33 and Serial No.06R0814506, Charge Air Cooler, Electronic Pre-Combustion Chamber (also ECV), Direct Injected, Compression-Ignited, Turbo Charged, producing 630 bhp with 6 cylinders at 2100 rpm while consuming a maximum of 30.7gal/hr. This equipment powers a TugOther Model No.TM250 and Serial No.TM250226, rated at TBD.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
СО	1.27	gm/bhp-hr
NOx+NMHC	4.40	gm/bhp-hr
PM10	0.127	gm/bhp-hr
PM2.5	0.127	gm/bhp-hr
SOx	0.005	gm/bhp-hr

CONDITIONS:

Fee Schedule:1 (c) Rating:630bhp SIC:4581 SCC:20200102 Location/UTM(Km):473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

ComAV Technical Services LLC 18438 Readiness Street Victorville,CA92394

By: COPY
Brad Poiriez
Air Pollution Control Officer

Page 1 of 2 Permit:B010912 Issue Date:12/06/2021

- 1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 1302 (C)(2)(a)]
- 2.This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) per CARB Diesel or equivalent requirements; or alternative diesel fuel or CARB diesel fuel utilizing fuel additives that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines.

 [Title 17 CCR 93116.3(a)]

Note: Use of CARB Certified ULSD fuel satisfies this requirement.

- 3. This engine and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. (This system must be moved for a valid business purpose annually.)
 [District Rules 1302, 1303, and 1320 and Title 17 CCR 93116.2(a)(29)]
- 4.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time. [District Regulation XIII NSR; Title 17 CCR 93116.4(c)(2)(A)]
- 5. This engine shall not operate for more than 4 hours in any one day, nor more than 100 hours in any consecutive 12 month period. Before this limitation can be increased, the facility is required to submit to the District an application to modify the permit, which may trigger BACT review and may necessitate a Health Risk Assessment (HRA). In addition, public notice and/or a commenting period may be required

[District Rules 1302, 1303, and 1320]

- 6.This engine, part of a large portable fleet, shall not operate within the state of California on or after January 1, 2022. [17 CCR 93116.3(c)]
- 7.The o/o shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:
- a. Date of each use and duration of each use (in hours);
- b. Reason for use (Regular use, testing & maintenance, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in gallons) or total hours; and,
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log). [Title 17 CCR 93116.4(c)]
- 8. This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Portable Compression Ignition Engines (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern. [District Rule 1302 and Title 17 CCR 93116]
- 9. This engine may be relocated throughout the Southern California Logistics Airport (SCLA) in support of operations without prior notification being sent to the District, but shall not be used within 1000 meters of any K-12 school, residence, hospital, or other sensitive receptor location. Sensitive receptor locations include, but are not limited to, hospitals, schools, and day care centers, and such other locations as the District board or California Air Resources Board may determine.

 [District Rule 204 and H&S Code 42705.5(a)(5)]
- 10.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

 [District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]

Page 2 of 2 Permit:B010912 Issue Date:12/06/2021