



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

B011756

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: APRIL 2026

OWNER OF OPERATOR (Co. #453)

Victor Valley Wastewater Reclamation Authority
20111 Shay Road
Victorville, CA 92394

EQUIPMENT LOCATION (Fac. #3433)

VVWRA - Hesperia Plant Lift Station
14400 Fresno Street
Hesperia, CA 92345

Description:

WASTEWATER TREATMENT, LIFT STATION FACILITY consisting of:

EQUIPMENT

Capacity	Equipment Description
0	Wet Well #1 and #2, each measuring 10.5' L x 15' W with maximum volume of 9,425 gallons.
60	Sewage Pumps, Submersible Centrifugal 60 hp (prime, standby)
1	Exhaust Fan, 1 hp
0	AC Unit (singular) Capacity: 3.18KW
0	Generator (standby) Capacity: 200KW (Permit # E012662)

CONDITIONS:

1. This equipment shall only be operated/maintained in strict accord with manufacturer's/supplier's recommendations and/or federal, state, regional and local waste water discharge permits.

2. This facility shall not process more than 1.5 million gallons of waste water in any one day.

Fee Schedule: 1 (b)

Rating: 61bhp

SIC: 4952

SCC: 50100719

Location/UTM(Km): 473E/3808N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victor Valley Wastewater Reclamation
Authority
P.O. Box 370
Adelanto, CA 92301

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

3. An operations log shall be maintained on-site for at least two (2) years and be made available to MDAQMD personnel on request. This log shall contain, as a minimum, the amount of waste water processed each day.

4. The wastewater treatment lift station shall not operate unless the lift station wetwell enclosure is continuously vented to the biofilter with valid District permit C011757.

5. A flow indication device shall be installed to measure and record the wastewater throughput for each day of operation.

6. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]